

**BEFORE THE PUBLIC UTILITIES COMMISSION  
OF THE STATE OF COLORADO**

\* \* \* \* \*

RE: IN THE MATTER OF ADVICE NO. )  
1797-ELECTRIC OF PUBLIC SERVICE )  
COMPANY OF COLORADO TO REVISE )  
ITS COLORADO P.U.C. NO. 8- ) PROCEEDING NO. 19AL-\_\_\_\_\_E  
ELECTRIC TARIFF TO IMPLEMENT )  
RATE CHANGES EFFECTIVE ON )  
THIRTY-DAYS' NOTICE. )

**DIRECT TESTIMONY AND ATTACHMENTS OF CHAD S. NICKELL**

**ON**

**BEHALF OF**

**PUBLIC SERVICE COMPANY OF COLORADO**

**May 20, 2019**

**BEFORE THE PUBLIC UTILITIES COMMISSION  
OF THE STATE OF COLORADO**

\* \* \* \* \*

RE: IN THE MATTER OF ADVICE NO. )  
1797-ELECTRIC OF PUBLIC SERVICE )  
COMPANY OF COLORADO TO REVISE )  
ITS COLORADO P.U.C. NO. 8- ) PROCEEDING NO. 19AL-\_\_\_\_\_E  
ELECTRIC TARIFF TO IMPLEMENT )  
RATE CHANGES EFFECTIVE ON )  
THIRTY-DAYS' NOTICE. )

**DIRECT TESTIMONY AND ATTACHMENTS OF CHAD S. NICKELL**

**TABLE OF CONTENTS**

<b><u>SECTION</u></b>	<b><u>PAGE</u></b>
I. INTRODUCTION, QUALIFICATIONS, PURPOSE OF TESTIMONY, AND RECOMMENDATIONS .....	9
II. DISTRIBUTION FUNCTIONS AND ACTIVITIES .....	16
III. DISTRIBUTION CAPITAL BUDGET, PROJECT SELECTION, AND FUNDING	19
IV. DISTRIBUTION 2014-2018 CAPITAL ADDITIONS .....	25
A. Asset Health and Reliability .....	27
B. Capacity .....	32
C. New Business .....	34
D. Mandates .....	38
E. Fleet, Tools, and Equipment .....	39
V. DISTRIBUTION 2019 CAPITAL ADDITIONS .....	41
A. Asset Health and Reliability .....	42
B. Capacity .....	43
C. New Business .....	48
D. Mandates .....	49
E. Fleet, Tools, and Equipment .....	50
VI. DISTRIBUTION O&M .....	52

VII.	WILDFIRE MITIGATION .....	60
VIII.	AGIS CAPITAL ADDITIONS.....	74
A.	Advanced Distribution Management System (ADMS) and Geospatial Information System (GIS) .....	83
1.	ADMS and GIS Functions and Capabilities.....	83
2.	ADMS and GIS Implementation and Costs .....	89
B.	Advanced Metering Infrastructure (AMI) .....	96
1.	AMI Functions and Capabilities.....	96
2.	AMI Implementation, Costs, and Benefits .....	98
3.	AMI Benefits.....	105
C.	The Field Area Network (FAN).....	113
1.	FAN Functions and Capabilities .....	113
2.	FAN Implementation and Costs .....	118
D.	Integrated Volt-VAr Optimization (IVVO).....	120
1.	IVVO Functions and Capabilities.....	120
2.	IVVO Implementation and Costs .....	125
E.	Fault Location Isolation and Service Restoration (FLISR) and Fault Location Prediction (FLP) .....	131
1.	FLISR and FLP Functions and Capabilities .....	131
2.	FLISR and FLP Implementation and Costs.....	139
F.	Program and Change Management Supporting AGIS.....	142
IX.	AGIS O&M.....	147
X.	RELIABILITY .....	151
XI.	RECOMMENDATIONS AND CONCLUSION .....	159

**LIST OF ATTACHMENTS**

Attachment CSN-1	Distribution Capital Additions 2014–2018
Attachment CSN-2	Distribution Capital Additions 2019
Attachment CSN-3	Distribution O&M Expenses by Cost Element
Attachment CSN-4	Distribution O&M Expenses by FERC Account
Attachment CSN-5	Illustration of the principal components of the FAN

**GLOSSARY OF ACRONYMS AND DEFINED TERMS**

<b>Acronym/Defined Term</b>	<b>Meaning</b>
2014 Electric Rate Case	Proceeding No. 14AL-0660E
ADMS	Advanced Distribution Management System
AGIS	Advanced Grid Intelligence and Security
AGIS CPCN Settlement	Proceeding No. 16A-0588E
AMI	Advanced Metering Infrastructure
AMR	Automated Meter Reading
ANSI	American National Standards Institute
CIAC	Contribution in Aid of Construction
CDOT	Colorado Department of Transportation
Commission	Colorado Public Utilities Commission
Company	Public Service Company of Colorado
CPCN	Certificate of Public Convenience and Necessity
CPCN Projects	AMI, IVVO, and the components of the FAN that support these components
CPE	Customer Premise Equipment
CSG	Community Solar Gardens
DA	Distribution Automation
DER	Distributed Energy Resources
Distribution	Distribution Business Area
DSM	Demand Side Management
ECT	Electric Continuity Threshold

<b>Acronym/Defined Term</b>	<b>Meaning</b>
ENGO	Edge of Network Grid Optimization
ERT	Electric Restoration Threshold
FAN	Field Area Network
FERC	Federal Energy Regulatory Commission
FLISR	Fault Location Isolation System Restoration
FLP	Fault Location Prediction
FPIP	Feeder Performance Improvement Program
GB CMD	Green Button Connect My Data
GFCI	Ground Fault Circuit Interrupter
GIS	Geospatial Information System
HAN	Home Area Networks
HTY	Historical Test Year
IEEE	Institute of Electrical and Electronics Engineers
IT	Information Technology
IVVO	Integrated Volt-VAr Optimization
kVAr	Kilovolt-Amperes Reactive
kW	Kilowatt
kWh	Kilowatt Hours
LED	Light-Emitting Diode
LTCs	Load Tap Changers
MHT	Mountain Hazard Tree
NIC	Network Interface Cards

<b>Acronym/Defined Term</b>	<b>Meaning</b>
NREL	National Renewable Energy Laboratory
OH	Overhead
O&M	Operations and Maintenance
OMS	Outage Management System
OpCos	Xcel Energy Operating Companies
PMO	Project Management Office
PTMP	Point-to-Multipoint
PTT	Productivity Through Technology
Public Service	Public Service Company of Colorado
QSP	Quality Service Plan
RFP	Request for Proposal
RFx	Request for Information and Pricing
ROW	Right of Way
RWT	Reliability Warning Threshold
SAIDI	System Average Interruption Duration Index
SAIFI	System Average Interruption Frequency Index
SCADA	Supervisory Control and Data Acquisition
Settlement Agreement	Non-Unanimous Comprehensive Settlement Agreement
SMS	Sensor Management System
SVC	Secondary Static VAR Compensators
TOU	Time-of-Use

<b>Acronym/Defined Term</b>	<b>Meaning</b>
UG	Underground
WAN	Wide Area Network
WiMAX	Worldwide Interoperability for Microwave Access
WiSUN	802.15.4g Standard
Xcel Energy	Xcel Energy, Inc.
XES	Xcel Energy Services Inc.
XLPE	Non-Jacketed Cross-Linked Polyethylene



**BEFORE THE PUBLIC UTILITIES COMMISSION  
OF THE STATE OF COLORADO**

\* \* \* \* \*

RE: IN THE MATTER OF ADVICE NO. )  
1797-ELECTRIC OF PUBLIC SERVICE )  
COMPANY OF COLORADO TO REVISE )  
ITS COLORADO P.U.C. NO. 8- ) PROCEEDING NO. 19AL-\_\_\_\_\_E  
ELECTRIC TARIFF TO IMPLEMENT )  
RATE CHANGES EFFECTIVE ON )  
THIRTY-DAYS' NOTICE. )

**DIRECT TESTIMONY AND ATTACHMENTS OF CHAD S. NICKELL**

1 I. **INTRODUCTION, QUALIFICATIONS, PURPOSE OF TESTIMONY, AND**  
2 **RECOMMENDATIONS**

3 **Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

4 A. My name is Chad S. Nickell. My business address is 1123 West 3<sup>rd</sup> Avenue,  
5 Denver, Colorado 80223.

6 **Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT POSITION?**

7 A. I am employed by Xcel Energy Services Inc. (“XES”) as Manager, System  
8 Planning and Strategy—South. XES is a wholly-owned subsidiary of Xcel  
9 Energy Inc. (“Xcel Energy”), and provides an array of support services to Public  
10 Service Company of Colorado (“Public Service” or the “Company”) and the other  
11 utility operating company subsidiaries of Xcel Energy on a coordinated basis.

12 **Q. ON WHOSE BEHALF ARE YOU TESTIFYING IN THE PROCEEDING?**

13 A. I am testifying on behalf of Public Service.

1 **Q. PLEASE SUMMARIZE YOUR RESPONSIBILITIES AND QUALIFICATIONS.**

2 A. As the Manager of Distribution System Planning & Strategy—South, I am  
3 responsible for providing strategic direction for building the Company’s  
4 distribution plan, and for ensuring a reliable and cost-effective electric distribution  
5 system. My duties include developing and leading a system modernization and  
6 renewal strategy and managing the Distribution capital budget for Public Service  
7 and Southwestern Public Service Company, one of the other Xcel Energy  
8 operating companies (“OpCos”). A description of my qualifications, duties, and  
9 responsibilities is set forth after the conclusion of my testimony in my Statement  
10 of Qualifications.

11 **Q. WHAT IS THE PURPOSE OF YOUR DIRECT TESTIMONY?**

12 A. The purpose of my Direct Testimony is multi-fold. First, in Sections IV through VI  
13 I support the \$1.294 billion of the Company’s Distribution Business Area  
14 (“Distribution”) plant in-service additions since the last rate case (not including  
15 Advanced Grid Intelligence and Security (“AGIS”)) as well as forecasted  
16 Distribution plant-in-service additions for calendar year 2019 of \$205.9 million  
17 (not including AGIS or Wildfire Mitigation), which are appropriately allocated to  
18 Public Service retail electric and included in the 2018 Historical Test Year  
19 (“HTY”) cost of service that is presented by Company witness Ms. Deborah A.  
20 Blair. Company witness Ms. Laurie J. Wold has calculated the monthly plant  
21 balances to develop the plant-related roll forward, which in turn is used by  
22 Company witness Ms. Blair to incorporate the year-end plant in service balances

1 into the 2018 HTY cost of service. I also support the \$105.4 million in 2018  
2 Operations and Maintenance (“O&M”) expense (pre-adjustment) included in the  
3 2018 HTY cost of service. These dollar figures also do not include costs  
4 associated with the AGIS initiative, which I discuss below. As part of my support  
5 for Distribution’s O&M expenses, I support the proposed adjustment to remove  
6 the Company’s incremental Distribution O&M expenses associated with providing  
7 mutual aid to Puerto Rico after Hurricane Irma in 2018. The Company’s last rate  
8 case was Proceeding No. 14AL-0660E (“2014 Electric Rate Case”), in which a  
9 2013 HTY was approved, therefore I am supporting the incremental capital  
10 investments from year-end 2013 through year-end 2019 with my testimony here.

11 Second, in Section VII of my Direct Testimony, I support the recovery of  
12 capital and O&M costs associated with Distribution’s updated Wildfire Mitigation  
13 Plan, including planned capital additions and O&M costs for 2019 included as an  
14 adjustment in the 2018 HTY cost of service. I also discuss Distribution’s Wildfire  
15 Mitigation activities going forward.

16 Next, in Section VIII, I discuss and support the technical strategy for  
17 implementation of the AGIS initiative, and the activities undertaken by the  
18 Company, which will result in an advanced electric distribution grid in the  
19 Company’s service territory. I explain how Distribution has started moving  
20 forward from the Commission approved settlement of the Certificate of Public  
21 Convenience and Necessity (“CPCN”) for AGIS (“AGIS CPCN” or “Grid CPCN”)  
22 in Proceeding No. 16A-0588E (“AGIS CPCN Settlement”) to implement the AGIS

1 CPCN projects, while also implementing those components of AGIS that are  
2 being conducted in the ordinary course of business. Through my discussion of  
3 the AGIS projects in Section VIII, I support Distribution's capital additions related  
4 to AGIS projects through 2018 of \$13.8 million, and the Company's forecasted  
5 2019 capital additions of \$71.4 million.

6 In Section IX, I support Distribution's AGIS-related O&M expenses for  
7 2018 as well as an adjustment to account for the known and measurable O&M  
8 that the Company anticipates for its AGIS-related Distribution O&M in 2019,  
9 which are included in the Company's 2018 HTY cost of service presented by Ms.  
10 Blair.

11 I note that Company witness Ms. Brooke A. Trammell introduces the  
12 proposed cost recovery methodology related to the AGIS programs and  
13 discusses the policy aspects of the AGIS initiative for this rate review, and that  
14 Company witness Mr. David C. Harkness provides support for the Business  
15 Systems organization's implementation of the Information Technology ("IT") for  
16 the AGIS projects.

17 Finally, in Section X, I discuss the Company's distribution reliability  
18 achievements to date and its plans for additional enhancements in the years  
19 ahead.

1 **Q. WHAT IS “AGIS”?**

2 A. We have visited with this Commission and interested stakeholders on various  
3 occasions previously about AGIS, but for those that haven’t had the opportunity  
4 to engage on this topic or are new interested parties, AGIS is a long-term  
5 strategic initiative that will transform the Company’s electrical distribution  
6 business by enhancing security, efficiency, and reliability, which will enable us to  
7 safely integrate more distributed resources, and improve customer products and  
8 services. The technical capabilities of the current grid are limited compared to  
9 more advanced grid technologies, and the overall system as presently configured  
10 is opaque—meaning the Company has little near real-time insight into the grid  
11 beyond the substation level. AGIS seeks to take advantage of existing advanced  
12 technology to increase grid reliability, transparency, efficiency, and access.  
13 Overall, the AGIS platform consists of multiple programs that will ultimately work  
14 together to support improved distribution technology, empowered customer  
15 choice, and improved energy management and savings. Consistent with related  
16 initiatives by utilities around the country, it is the natural next step in the  
17 development of our distribution grid.

18 The advanced grid that will be achieved through the Company’s AGIS  
19 initiative involves the following key programs, commonly referred to as  
20 “foundational” programs: Advanced Distribution Management System (“ADMS”);  
21 the Geospatial Information System (“GIS”); Advanced Meter Infrastructure  
22 (“AMI”); a Field Area Network (“FAN”); and advanced applications—such as

1 Integrated Volt-VAr Optimization (“IVVO”), Fault Location Isolation and Service  
2 Restoration (“FLISR”), and Fault Location Prediction (“FLP”)—that will utilize  
3 intelligent field devices. In addition, there are several projects and programs in  
4 development that will become part of the AGIS initiative beyond 2019. As a  
5 result, Public Service is not including those costs or forecasts as part of this rate  
6 review.

7 As noted above, in Section VIII of my testimony, I provide an overview of  
8 the AGIS initiative and discuss the implementation of the individual AGIS  
9 programs, detailing the type of work Distribution will complete, particularly where  
10 Distribution is taking the lead on budget development, planning, and deployment.  
11 I also support Distribution’s AGIS-related capital plant-in-service additions. In  
12 Section IX, I discuss Distribution’s AGIS-related O&M expenses.

13 **Q. ARE YOU SPONSORING ANY ATTACHMENTS AS PART OF YOUR DIRECT**  
14 **TESTIMONY?**

15 A. Yes, I am sponsoring Attachments CSN-1 through CSN-5, which were prepared  
16 by me or under my direct supervision. The attachments are as follows:

- 17 • Attachment CSN-1: Distribution Capital Additions 2014–2018;
- 18 • Attachment CSN-2: Distribution Capital Additions 2019;
- 19 • Attachment CSN-3: Distribution O&M Expenses by Cost Element;
- 20 • Attachment CSN-4: Distribution O&M Expenses by Federal Energy  
21 Regulatory Commission (“FERC”) Account; and
- 22 • Attachment CSN-5: Illustration of the principal components of the FAN.

1 **Q. WHAT RECOMMENDATIONS ARE YOU MAKING IN YOUR DIRECT**  
2 **TESTIMONY?**

3 A. As part of approving the cost of service developed by Ms. Blair, I recommend  
4 that the Colorado Public Utilities Commission (“CPUC” or “Commission”) approve  
5 the 2014-2019 Distribution Business Area capital additions and 2018 Distribution  
6 Business Area O&M expenses, including the AGIS capital additions and O&M set  
7 forth below. I also recommend the Commission approve the Company’s request  
8 related to recovery of Distribution-related Wildfire Mitigation Plan O&M expenses,  
9 which comprise an adjustment to the 2018 O&M expenses for known and  
10 measurable expenses.

1                   **II.     DISTRIBUTION FUNCTIONS AND ACTIVITIES**

2   **Q.     WHAT IS THE PURPOSE OF THIS SECTION OF YOUR TESTIMONY?**

3   A.     In this section, I describe the functions of the Distribution Business Area,  
4           including its key aspects and services. I also provide an overview of Public  
5           Service's distribution system.

6   **Q.     PLEASE DESCRIBE THE DISTRIBUTION BUSINESS AREA.**

7   A.     The Distribution Business Area is responsible for the construction and operation  
8           of Public Service's distribution system, which is the portion of its electric system  
9           that delivers electricity to the vast majority of our customers. The Distribution  
10          Business Area is comprised of the following functional areas: (1) Electric  
11          Distribution Design, Construction, and Maintenance; (2) Electric Distribution  
12          Engineering; (3) Business Operations; and (4) Planning and Performance. There  
13          are a total of approximately 1,132 operating company and XES Distribution  
14          employees assigned to provide services to the Public Service distribution system.  
15          Of those employees, approximately 1,055 are Public Service employees.

16   **Q.     PLEASE DESCRIBE THE KEY FUNCTIONS AND SERVICES OF THE**  
17          **DISTRIBUTION BUSINESS AREA.**

18   A.     The key services provided by the Distribution Business Area include developing  
19          infrastructure to serve new customers, restoring service after outages,  
20          performing routine maintenance, and making capital improvements when  
21          necessary to improve the performance and reliability of the distribution system.



1 To deliver these services, the Distribution Business Area is structured around  
2 four key functions:

3 • *Operations:* Includes the design, construction, and maintenance of the  
4 distribution system, as well as monitoring and operating the distribution  
5 system from the Electric Control Center, responding to electric distribution  
6 trouble calls, and coordinating emergency response.

7 • *Engineering:* Includes technical support and system planning, design,  
8 construction, and material standardization, reliability planning, and addressing  
9 distribution-related customer service issues.

10 • *Business Operations:* Includes vegetation management, outdoor lighting,  
11 metering systems and support, facility attachments, and the builder's call line.

12 • *Planning and Performance:* Includes business planning, consulting, and  
13 analytical services and performance governance and management.

14 **Q. PLEASE PROVIDE AN OVERVIEW OF PUBLIC SERVICE'S DISTRIBUTION**  
15 **SYSTEM.**

16 A. To reliably and efficiently serve our approximately 1.5 million Colorado  
17 customers, Public Service owns and operates an extensive electric distribution  
18 system. Our electric distribution system has assets in 25 counties and provides  
19 service to both rural and urban customers. The distribution system consists of  
20 approximately 151 distribution-level substations that support a network of 785  
21 distribution feeders necessary to serve our customers. Our distribution system is  
22 further comprised of 9,569 circuit miles of overhead distribution lines, 13,202

1 circuit miles of underground distribution lines, and over 400,000 poles. To  
2 operate and maintain this extensive system, the Distribution Business Area has  
3 wide-ranging control center operations and a fleet of over 330 support vehicles.

1     **III.     DISTRIBUTION CAPITAL BUDGET, PROJECT SELECTION, AND FUNDING**

2     **Q.     WHAT IS THE PURPOSE OF THIS SECTION OF YOUR DIRECT**  
3     **TESTIMONY?**

4     A.     The purpose of this section of my Direct Testimony is to provide an overview of  
5     the Distribution Business Area's capital budgeting process, project development,  
6     and budget management processes.

7     **Q.     WHAT ARE THE PRIMARY DRIVERS AFFECTING PUBLIC SERVICE'S**  
8     **DISTRIBUTION UTILITY CAPITAL ADDITIONS?**

9     A.     System growth, capacity expansion, and replacement for normal wear and tear of  
10    our electric distribution assets and fleet vehicles drive the need for capital  
11    additions to the system in order to: (1) ensure safety, quality of service, and  
12    financial prudence, while also (2) satisfying environmental and other legal and  
13    regulatory requirements. These business drivers in turn influence the amount  
14    and type of infrastructure we need to provide service to our customers, including:  
15    poles, wires, cross-arms, protective equipment, meters, transformers, switches,  
16    and street light equipment. To ensure the health of our distribution system and to  
17    meet the needs of our new and existing customers, as a general matter the  
18    Distribution Business Area undertakes projects to either (1) support existing  
19    customers, or (2) provide electric service to new customers.

1 **Q. WHAT ARE THE CORE CAPITAL BUDGET GROUPINGS THAT REFLECT**  
2 **THE DISTRIBUTION BUSINESS AREA'S GOALS AND DETERMINE ITS**  
3 **DISTRIBUTION INVESTMENTS?**

4 A. The Distribution Business Area has a well-defined process for identifying and  
5 determining electric distribution investments within five capital budget groupings  
6 encompassing our business area responsibilities. These categories include:

- 7 • *Asset Health and Reliability:* Projects classified as Asset Health and  
8 Reliability are related to infrastructure that is reaching the end of its useful life  
9 and is experiencing high failure rates – and that, as a result, negatively impact  
10 reliability of service while increasing O&M expenses. It also includes public  
11 damage and efficiency programs. Distribution assets are monitored to ensure  
12 that they provide reliable service throughout the year. When poor-performing  
13 assets are identified, projects that will improve asset performance are  
14 included in the budget. Examples of these types of projects include replacing  
15 underground tap and feeder cable, Feeder Performance Improvement  
16 Program (“FPIP”) projects along with other projects to address equipment and  
17 customers experiencing multiple interruptions. This category also includes  
18 replacement of wood poles and overhead lines that have reached the end of  
19 their useful life, replacing failed substation equipment, and replacing  
20 substation transformers and switchgear, and public damage.
- 21 • *Capacity:* This category includes all distribution system equipment  
22 associated with upgrading or increasing capacity to handle system load

1 growth and serve load under single contingency outage conditions (i.e., when  
2 one element of the distribution system is out of service). The work includes  
3 installation of new or upgraded substation transformers and distribution  
4 feeders. Capacity projects generally span multiple years and are  
5 necessitated by increased load either from existing customers or new  
6 customers. The investment varies between years depending on the type of  
7 work being completed. The installation of a brand new substation or the  
8 reconfiguration of an urban substation can be significantly more costly than  
9 additions to existing suburban substations. The Company prioritizes projects  
10 based on system need – which is defined as having enough available  
11 capacity to maintain the ability to serve additional load and the ability to  
12 provide backup support and switching capability when there is an outage.  
13 The Company will fund projects over its five-year budget period based on  
14 when a project is needed, the cost of projects, and actual spend. For  
15 instance, a capacity project in a high growth area could be funded sooner  
16 than a capacity project in a low growth area as the need is more immediate.

- 17 • *New Business:* This work includes new overhead and underground  
18 extensions and services associated with extending facilities to new  
19 customers, purchases of transformer and metering equipment, street lighting,  
20 and light-emitting diode (“LED”) street lights. Projects required to support this  
21 growth include the installation of feeders, primary and secondary extensions,  
22 street lights and service laterals.

1           • *Mandates:* This category includes poles, wire, labor, and other costs  
2 associated with both the relocation of existing plant and the location of certain  
3 new plant, to meet federal, state, or local requirements. These projects  
4 include relocating facilities that are in direct conflict with street expansions  
5 within public right-of-ways (“ROW”), undergrounding of facilities as required  
6 by franchise agreements or other authority, and safety-related work required  
7 by a governing authority. These projects are normally identified during  
8 planning meetings with local communities. Examples of these projects  
9 include relocations for state and local governments such as the Central 70  
10 project, which involves relocation across the I-70 corridor. These projects are  
11 monitored monthly and adjustments are made based on customer requests  
12 and any changes in operational mandates.

13           • *Fleet, Tools, and Equipment:* The Fleet, Tools, and Equipment category  
14 includes fleet, tools, ROW, land, communications, and locate costs  
15 associated with modifications or additions to the distribution system or  
16 supporting assets. Fleet costs represent the necessary replacement of  
17 vehicles and equipment that have become less reliable over time and more  
18 costly to maintain. ROW costs include capital additions associated with  
19 obtaining ROW and easements.

20           Within each of these categories, we identify both routine and individual  
21 projects based on the nature of the work we anticipate undertaking to continue to

1 serve existing customers, and to meet the needs of new customers on our  
2 distribution system.

3 **Q. PLEASE OUTLINE HOW THE DISTRIBUTION BUSINESS AREA IDENTIFIES**  
4 **AND FUNDS PROJECTS.**

5 A. First, we prioritize, fund, and undertake those projects that are necessary to  
6 maintain Public Service's distribution system to enable Public Service to provide  
7 safe and reliable electric service to our existing customers. As noted above,  
8 Public Service's distribution system is extensive and it is necessary to make  
9 regular investments that support the ongoing health and reliability of the system.  
10 These projects can be routine or individual. Examples of individual projects  
11 include the Proactive Cable Replacement program, where we systematically  
12 replace cables that have failed, and Overhead Rebuild projects, including the  
13 conversion of 4 kV feeders to 13.2 kV. This allows us to increase the efficiency  
14 and reliability of our feeder level network. We also monitor, fund and undertake  
15 reconstruction investments for road moves, as necessary.

16 Second, we make investments necessary to expand our system to serve  
17 new customers on the system. These investments include equipment purchases  
18 and installation. Expansion of our distribution system may involve both overhead  
19 and underground extensions, and substation and distribution line projects.

20 To support continued reliable service to existing customers and extension  
21 of service to new customers, we also incur costs for fleet purchases, tool and  
22 equipment purchases, street lighting, ROW work, and facility locates.

1 **Q. WHAT PROCESS DOES PUBLIC SERVICE FOLLOW TO MANAGE AND**  
2 **CONTAIN ITS DISTRIBUTION CAPITAL COSTS?**

3 A. The engineering department within the Distribution Business Area monitors all  
4 Distribution capital dollars to ensure that authorized projects align with the  
5 established budget. We perform a monthly project forecasting exercise to ensure  
6 we have a steady and dependable flow of financial information regarding capital  
7 expenditures. We then compare our monthly expenditures to our budgets, and  
8 any variances are addressed. Any project that may be outside of allowed  
9 variances is reevaluated, and may be escalated to management or the corporate  
10 level as appropriate. Reviews are also performed to compare year-to-date actual  
11 performance with year-to-date and year-end forecasts. Deviations are identified  
12 and recommendations to meet financial targets are reviewed and approved.

13 There is often emergent work in the distribution area, due to storm  
14 damage or other unforeseeable circumstances. Given that, it is important that  
15 we have the flexibility to shift funding to meet changing circumstances that arise  
16 each year. When we have unexpected projects that require completion in a  
17 certain year, we fund these projects by deferring less urgent projects. This  
18 allows us to stay within our annual capital budget, while ensuring the safety and  
19 reliability of the distribution system – which is a top priority.



1                   **IV.    DISTRIBUTION 2014-2018 CAPITAL ADDITIONS**

2   **Q.    WHAT IS THE PURPOSE OF THIS SECTION OF YOUR DIRECT**  
3   **TESTIMONY?**

4   A.    The purpose of this section of my Direct Testimony is to discuss the major non-  
5   AGIS capital investments the Distribution Business Area has made since the  
6   Company's 2014 Electric Rate Case, in which a 2013 HTY was approved, that  
7   were placed into service through the end of 2018. I discuss the Company's 2019  
8   actual and forecasted capital additions in Section V, below.

9   **Q.    WHAT IS THE TOTAL DOLLAR AMOUNT OF NON-AGIS DISTRIBUTION**  
10   **CAPITAL ADDITIONS THAT PUBLIC SERVICE IS REQUESTING IN THIS**  
11   **CASE?**

12   A.    As reflected in Attachment CSN-1, the Company placed into service  
13   approximately \$1.294 billion (Total Company) for non-AGIS related Distribution  
14   Business Area capital additions for 2014-2018 (Total Company). Note that  
15   Attachment CSN-1 contains Distribution capital additions inclusive of the AGIS-  
16   related capital additions as well.

17   **Q.    PLEASE PROVIDE AN OVERVIEW OF PUBLIC SERVICE'S DISTRIBUTION**  
18   **PLANT ADDITIONS FROM 2014 THROUGH 2018.**

19   A.    The Table below reflects Distribution capital additions, placed in service from  
20   2014 through 2018, broken down by budget grouping. I discuss these capital  
21   additions by budget group below.

1  
2  
3  
4  
**Table CSN-D-1**  
**Distribution Capital Additions 2014-2018**  
**(Total Company)**  
**(Dollars in Millions)**

<b>Distribution Capital Additions 2014–2018*</b>					
<b>Category</b>	<b>2014</b>	<b>2015</b>	<b>2016</b>	<b>2017</b>	<b>2018</b>
<b>Asset Health and Reliability</b>	\$83.8	\$111.5	\$119.0	\$100.8	\$87.7
<b>Capacity</b>	\$79.4	\$50.4	\$31.2	\$31.4	\$62.5
<b>New Business</b>	\$55.2	\$50.3	\$64.7	\$74.3	\$95.6
<b>Mandates</b>	\$18.2	\$16.7	\$22.0	\$18.5	\$26.2
<b>Fleet, Tools, and Equipment</b>	\$12.9	\$22.9	\$14.4	\$18.5	\$26.0
<b>Total**</b>	<b>\$249.5</b>	<b>\$251.8</b>	<b>\$251.2</b>	<b>\$243.4</b>	<b>\$298.0</b>
* This table does not include Distribution's AGIS-related capital additions, which are discussed separately in Section VIII and shown in Table CSN-D-7. ** There may be differences between the sum of the individual category amounts and Total amounts due to rounding.					

5           These figures are stated on a Total Company (Public Service) basis,  
6           meaning that they include both electric utility-specific projects and common  
7           electric/gas projects stated at the total Public Service level.

8           Below I discuss the Company's 2014–2018 capital additions by driver  
9           category. I address the Company's 2019 planned capital additions in Section V,  
10          below.

1        **A. Asset Health and Reliability**

2        **Q. PLEASE DISCUSS THE PRIMARY DRIVERS OF DISTRIBUTION CAPITAL**  
3        **ADDITIONS RELATED TO ASSET HEALTH AND RELIABILITY SINCE THE**  
4        **2013 HTY.**

5        A. The primary drivers affecting the Company's capital additions related to Asset  
6        Health and Reliability since the 2013 HTY fall into two categories – "routine in  
7        nature," and "larger specific projects." Over several years prior to and through  
8        2014, the Company reviewed the age profile and overall reliability performance of  
9        key components of the distribution system (substation transformers and circuit  
10       breakers, overhead lines, wood poles, and underground cables). As a result of  
11       this review, we concluded that Public Service must increase the level of annual  
12       replacements of these key components to maintain the existing condition and  
13       reliability of the distribution system. We then developed replacement plans for  
14       these key components and utilized this data to develop our budget to address the  
15       long-term asset health of these components. This work has helped to enable a  
16       systemic, efficient replacement program.

17       **Q. ARE THERE OTHER FACTORS THAT HAVE IMPACTED CAPITAL**  
18       **ADDITIONS IN THIS AREA?**

19       A. Yes. Instances of more severe weather events have increased and, with it,  
20       capital expenditures associated with storm-related damage. For instance, the  
21       Company's 2016 storm-related capital spend was about \$6 million above Public  
22       Service's annual average, and these expenditures were largely placed in service

1 in 2017. Likewise, the Company replaced several substation transformers  
2 (Substation Category) in 2016 due to failures, which were completed and went  
3 into service in early 2017. This had the effect of raising 2017 capital additions in  
4 these categories above the levels we have historically experienced.

5 Within the Asset Health Budget group, capital additions can be further  
6 classified into the following categories: Overhead Rebuild/Poles, Cable  
7 Replacement and Assessment, Substation, and Underground Conversions. I will  
8 address each in turn.

9 **Q. PLEASE DESCRIBE CAPITAL ADDITIONS RELATED TO OVERHEAD**  
10 **REBUILD/POLES SINCE THE 2014 ELECTRIC RATE CASE.**

11 A. Public Service's distribution system has nearly 9,600 miles of overhead lines and  
12 over 400,000 poles serving our distribution customers. The Overhead  
13 Rebuild/Poles category refers to the replacement, rebuild, and refurbishment of  
14 overhead feeder, tap and secondary lines. This may include replacing a single  
15 pole or cross-arm, or completely rebuilding a section of line. The grouping  
16 contains a program to proactively rebuild aged and overhead lines that are  
17 reaching their end of life to improve service and reliability to our customers. The  
18 specific rebuild projects are determined by an engineering review of previous line  
19 performance and reliability measures, as well as visual inspection by qualified  
20 line personnel to evaluate the condition of the equipment. This category also  
21 includes storm costs incurred as a result of weather events that impact service to

1 our customers. In 2018, for example, the Company placed \$19.5 million in  
2 capital additions in service related to Overhead Rebuild/Poles.<sup>1</sup>

3 **Q. CAN YOU DESCRIBE THE COMPANY'S POLE REPLACEMENT PROGRAM**  
4 **IN MORE DETAIL?**

5 A. Yes. Public Service owns over 400,000 distribution poles in the state of  
6 Colorado. The average useful life of a pole is around 80 years. The goal is to  
7 replace poles prior to failure, but at or near the end of their useful life.

8 **Q. HOW DOES PUBLIC SERVICE DETERMINE WHAT POLES TO REPLACE?**

9 A. The Company tests its poles on a 12-year inspection cycle, which amounts to  
10 approximately 8.3 percent of our poles each year. Actual poles inspected each  
11 year can vary depending on a variety of factors including the rate of poles  
12 rejected in each region of the Company. In 2018, the Company experienced a  
13 reject rate (referring to a pole that has failed testing and needs to be either  
14 replaced or reinforced to ensure the physical integrity of the pole) of around 6.8  
15 percent.

16 **Q. WHAT IS INCLUDED IN THE CABLE REPLACEMENT AND ASSESSMENT**  
17 **CATEGORY LISTED IN ATTACHMENT CSN-1?**

18 A. Public Service's distribution system has over 13,000 miles of underground cable.  
19 The Cable category refers to the replacement of portions of this underground  
20 cable that have failed and thus reached the end of their useful life. The specific  
21 sections of cable selected for replacement are chosen based on reliability date,

---

<sup>1</sup> These are labeled as "OH Rebuilds" in Attachment CSN-1.

1 failure history, and in some cases, by historical performance of similar types and  
2 vintages of cable.

3 **Q. PLEASE DESCRIBE THE COMPANY'S CABLE REPLACEMENT**  
4 **PROGRAMS.**

5 A. The Company has three main cable replacement programs, the replacement of  
6 what is referred to as URD cable or tap level cable, the proactive replacement of  
7 feeder or mainline cable, and the emergency replacement of feeder or mainline  
8 cable. Cable failures are a main contributor to outages for customers who are  
9 served by underground facilities. As part of the Company's asset renewal  
10 program, the replacement of underground cable is one of the key targeted  
11 assets. Nearly one-fifth of the Company's underground cable is a type of cable  
12 (non-jacketed cross-linked polyethylene ("XLPE") cable) and vintage (installed  
13 prior to 1990) that is more prone to failures and has shorter useful life  
14 (approximately 45 years) than newer cable types. Since 2012 the Company has  
15 been able to reduce the number of cable failures when compared to predicted  
16 failures with its continued investment in cable replacement.

17 Given the critical nature of the service we provide and the disruptive  
18 impact an outage can have, we intend to continue to invest in our cable  
19 replacement programs with the aim of improving reliability for our customers. In  
20 2018, for example, the Company placed more than \$43.4 million in capital

1 additions into service related to replacing underground cable<sup>2</sup> that reached the  
2 end of its useful life.

3 **Q. PLEASE DESCRIBE THE COMPANY'S SUBSTATION CAPITAL ADDITIONS.**

4 A. Replacing substation equipment can mitigate some of the greatest reliability risks  
5 to our customers. Public Service has 151 substations that have distribution  
6 equipment and 278 transformers that include other substation equipment like  
7 breakers and switchgear. The substation category refers to the replacement of  
8 transformers, breakers, switchgear, and other substation equipment that has  
9 either failed or has reached the end of its useful life. The specific equipment that  
10 is chosen to be proactively replaced is managed by our Substation System  
11 Performance group based on the age, condition, and by historical performance of  
12 similar types of equipment. The 2018 capital additions, for instance, included  
13 replacement of transformers at the Arvada Substation, Romeo Substation  
14 (located in San Luis Valley area), substation breakers that reached the end of  
15 their useful lives, and renewal of other general substation equipment.

16 **Q. PLEASE DESCRIBE THE COMPANY'S UNDERGROUND CONVERSION**  
17 **CAPITAL ADDITIONS.**

18 A. Public Service has over 9,500 miles of overhead line and more than 13,000 miles  
19 of underground line serving our distribution customers. The Underground  
20 Conversion category primarily refers to the conversion of distribution lines from  
21 overhead to underground. This category is also used to describe work to

---

<sup>2</sup> These are labeled as "Cable Replacement and Assessment" in Attachment CSN-1.

1 upgrade and replace underground equipment based on the age, performance,  
2 and condition. The need for conversion may be driven by customer request,  
3 redevelopment requirements, franchise requirements, or the condition of the  
4 equipment. In this way, these capital additions are often outside of the  
5 Company's control. That said, the Company also has a program to proactively  
6 replace aged network protectors and isolation boxes that have reached the end  
7 their useful life in our Downtown Denver underground network system.  
8 Proactively replacing these pieces of equipment helps maintain safe working  
9 conditions for our employees, and also avoids reliability risk to network  
10 customers. Another program within this category is the replacement of switch  
11 cabinets. These cabinets typically serve customer load in residential areas, and  
12 failure may result in extended outages to many customers. As an illustrative  
13 example, the Company placed \$18.1 million in capital additions in service related  
14 to Underground Conversions in 2018.<sup>3</sup>

15 **B. Capacity**

16 **Q. PLEASE DISCUSS THE PRIMARY DRIVERS OF DISTRIBUTION CAPITAL**  
17 **ADDITIONS RELATED TO CAPACITY SINCE THE 2013 HTY.**

18 A. The primary drivers of the Company's capital additions related to Capacity  
19 projects since the 2013 HTY include new substations, expansion of existing  
20 substations, addition of new feeders, and upgrades of existing equipment.  
21 Capacity projects generally involve fewer projects and are typically the

---

<sup>3</sup> These are labeled as "UG Conversions" in Attachment CSN-1.



1 Company's largest distribution capital expense. As a result, there is some  
2 variation year over year in capital additions, based on the cost and magnitude of  
3 projects and when projects go in-service. The annual capital expenditures from  
4 2014-2018 have been relatively flat, typically in the \$50-60 million range;  
5 however, these capital additions can fluctuate annually due to the size and  
6 duration of each project. Below are illustrative examples of some of the Capacity  
7 projects Public Service placed into service in 2018.

- 8 • *Sullivan #3 Project:* The Sullivan #3 Project included the addition of a third  
9 transformer and associated substation equipment and feeders at Sullivan  
10 Substation in Denver. The purpose of the project was to resolve existing  
11 system risks and to provide additional capacity to serve future load growth.  
12 The Company placed \$16.8 million in service in 2018 for the distribution  
13 portion of the project, of which \$11.1 million includes a substation transformer  
14 and the associated substation equipment, and \$5.8 million in feeder costs.
- 15 • *Moon Gulch Substation Project:* The Moon Gulch Project is a new distribution  
16 substation in Arvada. The purpose of the project was to provide additional  
17 capacity to serve load growth and development and to provide back-up and  
18 load transfer services to other substations in the area. The Company filed a  
19 CPCN application on November 25, 2015 in Proceeding No. 15A-0929E, and  
20 the Commission granted the CPCN on January 20, 2016. The Company  
21 placed \$14.5 million of capital additions in service in 2018, which consists of

1 the new substation, a 50 Mega Volt Amp (“MVA”) transformer and the  
2 associated substation equipment, and two new feeders.

- 3 • *Arrowhead Lake # 2 Project:* The Arrowhead Lake #2 Project included the  
4 addition of a second transformer and the associated substation equipment  
5 and feeders at Arrowhead Lake Substation in Greeley. The project was  
6 designed to add capacity and support the removal and decommissioning of a  
7 44 kV substation called Highlands. The Company placed \$11.9 million in  
8 capital additions in service in 2018, which consists of the new substation, a 50  
9 MVA transformer and the associated substation equipment, and two new  
10 feeders. The project is part of the overall Greeley master plan and removal of  
11 the 44 kV system which is needed to increase the reliability and load serving  
12 capability in and around the Greeley area.<sup>4</sup>

13 **C. New Business**

14 **Q. PLEASE DISCUSS THE PRIMARY DRIVERS OF DISTRIBUTION CAPITAL**  
15 **ADDITIONS RELATED TO NEW BUSINESS FROM THE 2013 HTY THROUGH**  
16 **2018.**


17 A. The primary drivers of the Company’s capital additions related to New Business  
18 projects since the 2013 HTY fall into four main categories – extensions,  
19 contribution in aid of construction (“CIAC”), street lights, and purchases of meters  
20 and transformers to support new business and replacements. New business

---

<sup>4</sup> See, e.g. Proceeding No. 17A-0146E, *In Re Public Service Application for Order Granting a Certificate of Public Convenience and Necessity for the Northern Greeley Area Transmission Plan Project* (filed Mar. 9, 2017).

1 needs are highly dependent on the state of the economy which, in turn, drive the  
2 number of requests for new service. Over the past several years, our new  
3 business investments have steadily increased. This increase is driven by growth  
4 in new housing construction, which is largely driven by strong economic  
5 conditions in Colorado. As reflected in Figure CSN-D-1 below, between 2014  
6 and 2018, the number of annual new meter sets has risen from 16,978 to 22,211  
7 respectively, representing a 30 percent increase over a four-year period.

8 **Figure CSN-D-1**  
9 **Public Service New Meter Sets – 2013-2018**  
10



11 Other factors that have driven capital additions from 2014 include a decrease in  
12 CIAC credits from expiring extensions which has decreased 2014 levels by more

1 than \$13 million or by about 55% (as explained in more detail below) and  
2 increases due to inflation and new customers requesting service within the  
3 Company's service territory.

4 **Q. PLEASE DESCRIBE IN MORE DETAIL THE COMPANY'S CAPITAL**  
5 **ADDITIONS FOR EXTENSIONS AND "EXPIRING EXTENSIONS."**

6 A. New housing growth necessitates new overhead and underground line  
7 extensions and associated service materials to serve new customers (including  
8 projects required to support this growth include the installation of feeders,  
9 primary and secondary extensions, and service laterals). Regarding the  
10 reduction in credits from expiring extensions, as described in the Company's  
11 electric tariffs, the "open extension period" is a ten-year span during which the  
12 Company calculates and pays refunds of customer construction payments  
13 according to provisions of this extension policy. At the end of the ten-year  
14 period, any remaining open extensions not credited back to customers are  
15 credited back to Distribution capital and offset some of the investments the  
16 Company makes on an annual basis. In recent years, there has been a  
17 decrease in credits for expiring extensions from a reduction in CIAC collected  
18 due being ten years out from the global recession and economic downturn  
19 starting in 2008.

1 **Q. PLEASE DESCRIBE THE COMPANY'S CAPITAL ADDITIONS RELATED TO**  
2 **STREET LIGHTING.**

3 A. The street lighting category includes any new street or area lights placed into  
4 service in 2018, as well as the reconstruction or rebuilding of street or area lights.  
5 Streetlight reconstruction or rebuild may include street lights that require  
6 replacement due to adverse weather impacts, public damage, or failed  
7 equipment.

8 **Q. PLEASE DESCRIBE THE COMPANY'S CAPITAL ADDITIONS RELATED TO**  
9 **TRANSFORMERS.**

10 A. The transformers category includes the purchase and installation costs of any  
11 distribution transformer and voltage regulator necessary to serve new or existing  
12 customers. Transformer purchases are primarily needed to serve new  
13 customers. Transformers in some instances require replacement due to  
14 increased customer demand, load, or in the event an existing transformers fails  
15 or malfunctions.

16 **Q. PLEASE DESCRIBE THE COMPANY'S METER CAPITAL ADDITIONS.**

17 A. The meters category includes the purchase and installation costs of distribution  
18 meters necessary to serve new or existing customers. Meter purchases are  
19 primarily for new customers in order to measure demand and energy at the point  
20 of delivery. Meters in some instances require replacement due to increased  
21 customer demand, load, or in the event an existing meter fails or malfunctions.

1        **D. Mandates**

2        **Q. PLEASE DISCUSS THE PRIMARY DRIVERS OF DISTRIBUTION CAPITAL**  
3        **ADDITIONS RELATED TO MANDATES SINCE THE 2013 HTY.**

4        A. The primary drivers of the Company's capital additions related to Mandate  
5        projects since the 2013 HTY generally fall into two main categories – relocating  
6        facilities that conflict with street expansions within public ROW and  
7        undergrounding facilities as pursuant to franchise agreements or other  
8        authorities. Similar to the New Business category, the volume of facility  
9        relocation projects is directly correlated to the state of the economy, which has  
10       been strong over the past five years. Examples of relocations include relocations  
11       of facilities in coordination with the Colorado Department of Transportation  
12       (“CDOT”) Central 70 project and electric distribution facilities that need to be  
13       relocated to accommodate the new alignment of I-70. Expenditures for  
14       undergrounding facilities pursuant to franchise agreements have generally  
15       remained flat year over year. Along with meeting our franchise requirements,  
16       these projects provide benefits to our customers in the form of a more reliable,  
17       resilient system, renewal of existing assets, and improved aesthetics.

18       **Q. PLEASE EXPLAIN WHAT UNDERGROUNDING PROJECTS ARE.**

19       A. Through franchise agreements the Company signs with local jurisdictions, the  
20       Company will underground existing overhead lines at the request of the local  
21       jurisdiction. As an illustrative example, the Company placed \$14.7 million of

1 capital additions in service related to undergrounding projects pursuant to  
2 franchise agreements in 2018.

3 **Q. PLEASE DESCRIBE RELOCATION PROJECTS.**

4 A. This category includes routine projects that consist of poles, wire, labor, and  
5 other costs associated with both the relocation of existing plant and the location  
6 of certain new plant, to meet federal, state, or local requirements. These projects  
7 include relocating facilities that are in direct conflict with street expansions within  
8 public ROWs, undergrounding of facilities as required by franchise agreements  
9 or other authority, and safety-related work required by a governing authority.

10 **E. Fleet, Tools, and Equipment**

11 **Q. PLEASE DISCUSS THE PRIMARY DRIVERS OF DISTRIBUTION CAPITAL**  
12 **ADDITIONS RELATED TO FLEET, TOOLS, AND EQUIPMENT SINCE THE**  
13 **2013 HTY.**

14 A. The primary drivers of the Company's capital additions related to Fleet, Tools,  
15 and Equipment since the 2013 HTY generally fall into five categories – fleet  
16 purchases, tools purchases, substation communication equipment, electric  
17 locates, and acquisition of ROW for distribution equipment. The capital  
18 expenditures within this category have generally been flat year over year, though  
19 the timing of in-servicing some of the larger fleet vehicles (such as bucket trucks)  
20 occasionally leads to variances. For example, the primary increase within this  
21 category is based on timing on fleet vehicles that were purchased at the end of

1 2017, but not in-serviced until 2018 (once the vehicles were “road ready”) along  
2 with the fleet vehicles that were purchased and in-serviced in 2018.

3 **Q. WHAT DO YOU CONCLUDE REGARDING THE COSTS FOR THE**  
4 **DISTRIBUTION BUSINESS AREA CAPITAL PROJECTS THAT WENT INTO**  
5 **SERVICE BETWEEN 2014 AND 2018?**

6 A. I conclude that these capital additions have been prudently incurred, reasonable  
7 in cost, and used and useful in supporting Public Service’s ability to provide safe  
8 and reliable electric service to its customers.



1                   **V.    DISTRIBUTION 2019 CAPITAL ADDITIONS**

2 **Q.    WHAT IS THE PURPOSE OF THIS SECTION OF YOUR DIRECT**  
3 **TESTIMONY?**

4 A.    The purpose of this section of my Direct Testimony is to provide an overview of  
5 the Distribution Business Area's forecasted capital additions not related to AGIS  
6 or the Company's Wildfire Mitigation Plan for 2019.

7 **Q.    PLEASE DESCRIBE THE 2019 DISTRIBUTION CAPITAL ADDITIONS YOU**  
8 **AER SUPPORTING FOR INCLUSION IN THIS RATE REVIEW.**

9 A.    I am supporting \$205.9 million in Distribution-related capital additions not related  
10 to AGIS or the Wildfire Mitigation Plan for inclusion in the 2018 HTY cost of  
11 service. Table CSN-D-2 below provides a breakdown of these capital additions  
12 by budget group.

1  
2  
3  
4  
**Table CSN-D-2**  
**Distribution Capital Additions 2019**  
**(Total Company)**  
**(Dollars in Millions)**

<b>Distribution Capital Additions 2019*</b>	
<b>Category</b>	<b>2019</b>
<b>Asset Health and Reliability</b>	\$96.1
<b>Capacity</b>	\$79.2
<b>New Business</b>	\$0.0
<b>Mandates</b>	\$24.3
<b>Fleet, Tools, and Equipment</b>	\$6.4
<b>Total**</b>	<b>\$205.9</b>
* This table does not include Distribution's AGIS-related capital additions, which are discussed separately in Section VIII and shown in Table CSN-D-7.	
** There may be differences between the sum of the individual category amounts and Total amounts due to rounding.	

5 Below I describe these capital additions by budget group (using the same  
6 budget groups as above, in Section IV, for the period 2014–2018), and describe  
7 approximately 90 percent of the portfolio of the Company's 2019 Distribution  
8 capital additions requested in this proceeding.

9 **A. Asset Health and Reliability**

10 **Q. PLEASE DESCRIBE THE COMPANY'S DISTRIBUTION CAPITAL ADDITIONS**  
11 **RELATED TO ASSET HEALTH AND RELIABILITY IN 2019.**

12 A. As discussed above in Section IV.A, within the Asset Health budget group, most  
13 capital additions fall into the following categories: Overhead Rebuild/Poles, Cable  
14 Replacement and Assessment, Substation, and Underground Conversions. The

1 activities undertaken by Distribution for each of these categories is described  
2 above in Section IV.A.

3 Total capital additions for Asset Health and Reliability projects for 2019 will  
4 be \$96.1 million, which is in-line with previous years and is representative of the  
5 continued execution on the Company's asset health and reliability programs.  
6 Capital additions by category include \$23.4 million for Overhead Rebuild/Poles,  
7 \$41.2 million for Cable Replacement and Assessment, \$11.3 million for  
8 Substation, \$18.0 million Underground Conversions, and \$2.2 million for Network  
9 Protectors.

10 **B. Capacity**

11 **Q. PLEASE DISCUSS THE COMPANY'S DISTRIBUTION CAPITAL ADDITIONS**  
12 **RELATED TO CAPACITY IN 2019.**

13 A. The primary categories of the Company's capital additions related to Capacity  
14 projects include: new substations, expansion of existing substations, addition of  
15 new feeders, and upgrades of existing equipment. As noted above in Section  
16 IV.B, Distribution generally has fewer capacity projects at any given time, and  
17 these projects are typically the Company's largest distribution capital expenses.  
18 As a result, there is some variation year over year in capital additions, based on  
19 the cost and magnitude of projects and when projects go in-service.

20 Total capital additions for Capacity projects in 2019 will be \$79.2 million.  
21 Key projects related to Capacity in 2019 include:

- 1           • *Thornton Project:* The Thornton Project is a new distribution substation in  
2 Thornton. The project includes the construction of a new substation in  
3 Thornton and the extension of the Fort-Lupton – Cherokee 115 kV  
4 transmission line to feed the substation.

5           The distribution portion of the project consists of installing a single 115  
6 kV/13.8 kV 50 MVA distribution transformer and the associated substation  
7 equipment, and will ultimately include two new distribution feeders. The  
8 purpose of the project is to provide additional capacity to serve load growth  
9 and development and to provide back-up and load transfer services to  
10 existing substations in the area.

11           The new substation site is located on the southeast corner of 120<sup>th</sup> and  
12 Holly Street, and the Company closed on the land on July 31, 2017, which  
13 placed the land in service in 2017. When complete, the site will include  
14 landscaping and an architectural wall that will have a similar architectural look  
15 as the Anything Library across the street.

16           The Company filed a CPCN on October 3, 2014 in Proceeding No.  
17 14A-1002E and the CPCN was granted on April 29, 2015. For the distribution  
18 portion of the project, the Company is forecasting \$22.7 million in capital  
19 additions to be placed into service in 2019.

- 20           • *Ennis Substation Project:* The Ennis Substation Project includes the addition  
21 of a new transformer and associated substation equipment and feeders at  
22 Ennis Substation in Keensburg. The purpose of the project is to provide

1 additional capacity to serve a single large oil and gas customer in the area.  
2 The Company is planning to place \$7.9 million in service in 2019 for the  
3 distribution portion of the project, of which \$7.1 million includes a substation  
4 transformer and the associated substation equipment, and \$0.8 million in  
5 feeder costs.

- 6 • *Rosedale #3 Project:* The Rosedale #3 Project included the addition of a new  
7 transformer and associated substation equipment and feeders at Rosedale  
8 Substation in Greeley. The purpose of the project was to resolve existing  
9 system risks, to provide additional capacity to serve future load growth, and to  
10 support the removal and decommissioning of a 44 kV substation Evans. The  
11 Company is planning to place \$11.0 million in service in 2019 for the  
12 distribution portion of the project, of which \$6.6 million includes a substation  
13 transformer and the associated substation equipment, and \$4.4 million in  
14 feeder costs.

- 15 • *Picadilly #2 Project:* The Picadilly #2 Project includes the addition of a new  
16 transformer and associated substation equipment and feeders at Picadilly  
17 Substation in Aurora. The purpose of the project is to resolve existing system  
18 risks and to provide additional capacity to serve future load growth. The  
19 Company is planning to place \$5.2 million in service in 2019 for the substation  
20 transformer and the associated substation equipment.

- 21 • *Pleasant Valley Substation Project:* The Pleasant Valley Substation Project  
22 includes a new 115kV substation called Cloverly Substation and is part of the

1 Northern Greeley Area Plan that received a CPCN from the Commission in  
2 Proceeding No. 17A-0146E. The purpose of the project is to support the  
3 decommissioning of the existing 44 kV Pleasant Valley substation and  
4 transmission lines which ultimately will improve the reliability and load serving  
5 capabilities in the area. The Company is planning to place \$6.0 million in  
6 service in 2019 for the substation transformer, the associated substation  
7 equipment, and the distribution feeders.

- 8 • *Alamosa Terminal Substation Project*. The Alamosa Terminal Substation  
9 Project includes a new transformer and associated substation equipment and  
10 feeders at Alamosa Terminal Substation in Alamosa. The purpose of the  
11 project is to resolve existing system risks, replace existing substation  
12 equipment that is nearing the end of useful life, and to provide additional  
13 capacity to serve future load growth. The Company is planning to place \$3.9  
14 million in service in 2019 for the substation transformer and the associated  
15 substation equipment.

16 **Q. HOW WERE COSTS FOR THE THORNTON PROJECT ADDRESSED IN THE**  
17 **COMPANY'S CPCN FILING?**

18 A. In its CPCN Application filed in Proceeding No. 14A-1002E, the Company  
19 estimated project costs at \$32.7 million, plus or minus 30 percent for the  
20 substation, transmission, and distribution feeders, with siting and land costs  
21 excluded. Highly Confidential Attachment JDL-1, attached to the Direct  
22 Testimony of John Lupo filed in Proceeding No. 14A-1002E, included the total

1 cost of the project which included land costs. The costs were highly confidential  
2 as the Company was still in negotiations to acquire the property at the time. This  
3 information is no longer highly confidential as the property for the substation has  
4 been acquired. With siting and land costs included, the Company estimated  
5 project costs to be \$34.2 million, plus or minus 30 percent.

6 **Q. HAS THE THORNTON PROJECT INCREASED IN COST SINCE THE**  
7 **COMMISSION ISSUED A CPCN?**

8 A. Yes. The project costs have increased for several reasons. As Company  
9 witness Ms. Kelly Bloch explained in her Direct Testimony (page 14 lines 7-17) in  
10 the CPCN proceeding (Proceeding No. 14A-1002E), the costs estimated in the  
11 CPCN were highly dependent on the location of the substation site. The  
12 Company's cost estimates in the CPCN application were based on its preferred  
13 siting area, which was located on the southeast corner of 136<sup>th</sup> Avenue and Holly  
14 Street. After receiving its CPCN, the Company encountered local opposition  
15 from the adjacent neighborhood, and was simultaneously approached by a  
16 nearby landowner about an opportunity to purchase a nearby parcel being  
17 annexed to the City of Thornton. Accordingly, the Company decided not to  
18 pursue local land use permits at its preferred site. The new site has resulted in  
19 higher land costs and higher site development costs that include landscaping, a  
20 detention pond, and other general development costs. This has increased the  
21 project cost by approximately \$5.5 million. The other major driver has been the  
22 engineering, staff, and consulting support for siting the new substation. The

1 project spend for siting and engineering support (excluding the land costs of the  
2 136<sup>th</sup> Avenue and Holly Street site) was approximately \$5 million through the end  
3 of 2016.

4 **Q. CAN YOU PROVIDE AN UPDATE ON THE THORNTON PROJECT?**

5 A. Yes. The Company's local land use permits for the 120<sup>th</sup> Avenue and Holly  
6 Street site were approved by the Thornton City Council on July 11, 2017, the  
7 Company successfully acquired the land on July 31, 2017, and the Company's  
8 local land use permits for the transmission transition structures were approved by  
9 Adams County on August 24, 2017. The Company has received all the  
10 necessary approvals, started construction in 2018, and is anticipating the  
11 substation will be placed in service in June 2019.

12 **C. New Business**

13 **Q. ARE YOU SUPPORTING ANY CAPITAL ADDITIONS FOR DISTRIBUTION  
14 NEW BUSINESS IN 2019?**

15 A. No. The New Business category contains projects that are revenue-producing,  
16 such as new overhead and underground extensions, extensions to serve new  
17 customers, purchases of transformer and metering equipment, and streetlighting.  
18 As explained in more detail in the Direct Testimony of Ms. Trammell, the  
19 Company is not including 2019 New Business capital additions that are revenue-  
20 producing in our 2019 capital reach request as an attendant impact of the  
21 Company's requested capital reach. This adjustment to the capital reach



1 recognizes and accounts for the fact that certain new capital additions can be  
2 directly attributed to incremental revenue.

3 **D. Mandates**

4 **Q. PLEASE DESCRIBE THE DISTRIBUTION CAPITAL ADDITIONS RELATED**  
5 **TO MANDATES IN 2019.**

6 A. The Company's capital additions related to Mandate projects in 2019 generally  
7 fall into two main categories: relocating facilities that conflict with street  
8 expansions within public ROW and undergrounding facilities as pursuant to  
9 franchise agreements or other authorities. Similar to the New Business category  
10 (discussed in Section IV above), the pervasiveness of facility relocation projects  
11 are generally dependent on the state of the economy, which has been strong  
12 over the past several years. The activities undertaken by Distribution for each of  
13 these categories is described above in Section IV.D.

14 Total capital additions for Mandates projects for 2019 will be \$24.3 million,  
15 which is down by \$1.9 million from 2018 levels. Capital additions by categories  
16 include \$13.0 million for undergrounding facilities pursuant to franchise  
17 agreements, and \$11.3 million for relocation of facilities in conflict with street  
18 expansions projects (including \$2.2 million of relocations for the Central 70  
19 project, which is described above in Section IV.D).

1        **E. Fleet, Tools, and Equipment**

2        **Q. PLEASE DISCUSS THE CATEGORIES OF DISTRIBUTION CAPITAL**  
3        **ADDITIONS RELATED TO FLEET, TOOLS, AND EQUIPMENT FOR 2019.**

4        A. The categories of the Company's capital additions related to "Fleet, Tools, and  
5        Equipment" have changed in 2019. Starting this year, Fleet purchases were  
6        moved from individual business unit budgets (such as Distribution) to Operations  
7        Services (which falls within the Shared Corporate Services Business Area) to  
8        gain efficiencies across the Xcel Energy operating companies for Fleet  
9        purchases. Accordingly, 2019 capital additions for Fleet purchases are  
10       supported in the Direct Testimony of Mr. Adam R Dietenberger. The remaining  
11       categories remain unchanged and include: tools purchases, substation  
12       communication equipment, electric locates, and acquisition of ROW for  
13       distribution equipment. As discussed above in Section IV.E, these expenditures  
14       have generally been flat year over year, though the timing of in-servicing some of  
15       the larger fleet vehicles (such as bucket trucks) occasionally had resulted in  
16       variances in the timing of plant additions.

17                Total capital additions for Tools, and Equipment for 2019 will be \$6.4  
18       million. Of the decrease from 2018 levels, \$16.1 million can be attributed to Fleet  
19       purchases, which have been moved from the individual business areas (such as  
20       Distribution) to Operations Services.

1 Q. HAS THE COMPANY, AND WILL THE COMPANY, MANAGE ITS  
2 PROJECTED DISTRIBUTION BUSINESS AREA-RELATED CAPITAL  
3 ADDITION PROJECTS IN 2019 TO ENSURE THE FINAL, ACTUAL COSTS  
4 ARE REASONABLE AND PRUDENT?

5 A. Yes.

1 **VI. DISTRIBUTION O&M**

2 **Q. WHAT IS THE PURPOSE OF THIS SECTION OF YOUR TESTIMONY?**

3 A. The purpose of this section of my testimony is to provide an overview of the  
4 Distribution Business Area non-AGIS O&M expenses, followed by a discussion of  
5 the 2013 HTY compared to actual 2018 Distribution Business Area O&M  
6 expenses, which the Company proposes to utilize as the primary basis for  
7 establishing Distribution O&M levels included in rates going forward. I also  
8 describe the drivers of O&M cost increases between 2013 and 2018, if  
9 applicable.

10 **Q. WHAT ARE THE TYPES OF COSTS THAT THE DISTRIBUTION BUSINESS**  
11 **AREA INCURS FOR O&M?**

12 A. To support the Company's Distribution assets, a variety of O&M work is  
13 performed by the Distribution Business Area. Distribution's O&M expenses  
14 includes labor costs associated with maintaining, inspecting, installing, and  
15 constructing distribution facilities such as poles, wires, transformers, and  
16 underground electric facilities. It also includes labor costs related to programs  
17 that include vegetation management, pole inspection, cable repairs, and damage  
18 prevention. Finally, it includes transportation costs and miscellaneous materials  
19 and minor tools necessary to build out, operate and maintain our electric  
20 distribution system. Specifically, the O&M component of fleet includes those  
21 expenses necessary to maintain our existing fleet. This includes annual fuel

1 costs plus the allocation of fleet support to O&M based on the proportion of the  
2 distribution fleet utilized for O&M activities as compared to capital projects.

3 The O&M expenses can be further broken down into the following six  
4 categories:

- 5 • *Internal Labor*: Internal labor costs are the employee costs associated with  
6 maintaining, inspecting, installing, and construction distribution facilities such  
7 as poles, wires, transformers, and underground electric facilities.
- 8 • *Contract Labor*: Contract labor costs are the costs associated with the use of  
9 contractors to support more specialized or seasonal tasks such as tree  
10 trimming, pole inspections, storm response, and underground facility location.
- 11 • *Materials*: Material costs are the material costs for maintaining and operating  
12 the distribution system such as braces, insulators, cross-arms, and splices.
- 13 • *Transportation*: Transportation costs are the costs associated with the use  
14 and maintenance of our fleet vehicles that is necessary to operate and  
15 maintain our electric distribution system.
- 16 • *Other*: Other costs include costs associated with employee expenses and  
17 miscellaneous expenses.
- 18 • *First Set Credits*: Consistent with general utility practice, Public Service  
19 capitalizes its transformers and meters when they are purchased (including  
20 the labor and transportation to install them). When the transformers and  
21 meters are purchased a credit is applied to O&M upon purchase to account  
22 for the expenses to install this equipment later. By providing this O&M credit,

1 we mitigate the double-counting that would occur for the installation of the  
2 equipment.

3 As I describe in more detail below, over 83 percent of the 2018  
4 Distribution O&M expenses are related to employee and contract labor. The  
5 remaining portions are comprised of fleet, materials, tools, employee expenses,  
6 and first set credits as explained above.

7 **Q. PLEASE PROVIDE AN OVERVIEW OF PUBLIC SERVICE'S DISTRIBUTION**  
8 **O&M EXPENSES SINCE ITS LAST 2014 ELECTRIC RATE CASE, WHICH**  
9 **WAS BASED ON A 2013 HTY.**

10 A. Table CSN-D-3, below, identifies the amount of overall O&M costs by the  
11 categories I listed above. Attachment CSN-3 and Attachment CSN-4 provide an  
12 accounting of these expenses by Cost Element and by FERC account (not  
13 including AGIS), respectively.

1  
2  
3  
4

**Table CSN-D-3:  
 Distribution 2018 versus 2013 Actual O&M Expenses  
 Public Service Electric  
 (Dollars in Millions)**

<b>Distribution 2018 versus 2013 Actual O&amp;M Expenses</b> (Dollars in Millions)*			
<b>Cost Category</b>	<b>2013</b>	<b>2018</b>	<b>Difference</b>
Internal Labor	32.5	39.1	6.6
Contract Labor	42.7	60.7	18.0
Materials	8.9	7.4	(1.5)
Transportation	7.5	8.3	0.8
Other	3.7	4.9	1.2
First Set Credits	(7.4)	(15.0)	(7.6)
<b>Total*</b>	<b>87.9</b>	<b>105.4</b>	<b>17.5</b>
<p>*There may be differences between the sum of the individual category program amounts and Total amounts due to rounding.            ** Dollar figures in this Table do not include AGIS-related O&amp;M expenses.</p>			

5 **Q. WHAT IS THE TOTAL DOLLAR AMOUNT OF DISTRIBUTION O&M THAT**  
 6 **YOU ARE SUPPORTING IN THIS CASE?**

7 A. As reflected in Attachment CSN-3, I support \$105.4 million of O&M expenses  
 8 (pre-adjustments) not related to AGIS. Attachment CSN-3 provides an  
 9 accounting of these expenses by Cost Element and Attachment CSN-4 provides  
 10 the O&M by FERC account.

11 **Q. IS THE \$105.4 MILLION (PRE-ADJUSTMENTS AND EXCLUDING AGIS) IN**  
 12 **2018 O&M COSTS YOU DESCRIBE IN TABLE CSN-D-3 ABOVE REFLECTED**  
 13 **IN THE 2018 HTY COST OF SERVICE PRESENTED BY MS. BLAIR?**

14 A. Yes.

1 Q. WHAT ARE THE MAJOR DIFFERENCES BETWEEN THE DISTRIBUTION  
2 BUSINESS AREA'S 2013 HTY AND 2018 ACTUALS?

3 A. Three major drivers explain the increase of \$17.5 million in O&M expenses from  
4 2013 to 2018. These are:

- 5 • Internal Labor has increased by \$6.6 million from 2013 to 2018. The average  
6 annual internal labor wage increase has been approximately 3 percent and is  
7 the primary driver of the 2013 to 2018 increase.
- 8 • Contract Labor has increased by \$18.0 million from 2013 to 2018.  
9 Approximately \$7 million is representative of the increase of the contract labor  
10 necessary to install transformers and meters, which is offset by the increase  
11 in credits for first set credits. Other increases include general inflation over  
12 the five-year period (around \$6.8 million) and the O&M expenses associated  
13 with contract designers necessary to meet the increased amount of work the  
14 Company is conducting on an annual basis, particularly to serve new  
15 customers.
- 16 • Material costs have decreased by \$1.5 million from 2013 to 2018. Material  
17 costs incurred tend to fluctuate year over year dependent on the type of O&M  
18 activities and the materials necessary to maintain and operate the electric  
19 distribution system.
- 20 • Transportation costs have increased by \$0.8 million from 2013 to 2018.  
21 Transportation costs tend to fluctuate year over year dependent on the cost of  
22 fuel and maintenance of fleet vehicles that is required in a given year.



- 1       • Other costs have increased by \$1.2 million from 2013 to 2018 and includes  
2       costs for employee expenses, safety equipment, and miscellaneous costs.
- 3       • First Set Credits have increased by \$7.6 million from 2013 to 2018, which is  
4       representative of the increase in meters and transformer purchases needed  
5       to meet an increased number of meter sets (and the number of new  
6       customers) between 2013 and 2018. The number of meter sets increased by  
7       over 9,500 meters during this time period due to the strong economic growth  
8       in Colorado, as described in more detail in the New Business section of my  
9       Direct Testimony.

10   **Q.   IS THE COMPANY PROPOSING KNOWN AND MEASURABLE**  
11   **ADJUSTMENTS TO ITS 2018 TEST YEAR COST OF SERVICE?**

12   A.   Yes. The Company is proposing an adjustment of \$5.3 million to eliminate the  
13   incremental Distribution O&M expenses associated with Mutual Aid to Puerto  
14   Rico the Company provided after Hurricane Irma in 2018. The expenses  
15   included contract labor, employee expenses, internal over-time labor, materials,  
16   and fleet as part of the Company's effort to help restore Puerto Rico's electric  
17   grid after Hurricane Irma. Adjustments related to aid to Puerto Rico are  
18   discussed by Company witness Ms. Blair. I discuss the Company's proposed  
19   Wildfire Mitigation adjustment in Section VII below, and AGIS O&M in Section  
20   VIII below.

1 **Q. IS THERE ANYTHING ELSE YOU WOULD LIKE TO DISCUSS RELATED TO**  
2 **THE COMPANY'S 2018 DISTRIBUTION O&M?**

3 A. Yes, there is one compliance item from a previous proceeding I would like to  
4 mention. In accordance with the Non-Unanimous Comprehensive Settlement  
5 Agreement ("Settlement Agreement") approved in consolidated Proceeding Nos.  
6 16AL-0048E, 16A-0055E, and 16A-0139E, Public Service committed to  
7 developing a study (the "Red Light / Green Light" demarcation study) to make  
8 available possible interconnection points on its system for Community Solar  
9 Gardens ("CSG").<sup>5</sup> The Settling Parties believed that certain constraints on the  
10 Company's distribution system may create an opportunity for Public Service to  
11 assist CSG developers in siting CSG facilities. Under the terms of the Settlement  
12 Agreement, the Settling Parties agreed that Public Service should receive  
13 deferred accounting treatment for the monies needed to complete the study, the  
14 cost of which would be capped at \$250,000. The Settling Parties further agreed  
15 that the recovery methodology would be determined at the time the Company  
16 requested recovery through rates.

17 Public Service initiated the Red Light / Green Light demarcation study in  
18 June 2017 and presented the results of the study on its website and introduced it  
19 to certain stakeholders in June 2018. The Red Light / Green Light study was  
20 completed internally by the Company meaning that there were no incremental

---

<sup>5</sup> Proceeding Nos. 16AL-0048E, 16A-0055E, and 16A-0139E, Non-Unanimous Comprehensive Settlement Agreement, pp. 61–62 (filed Aug. 15, 2016).

1 costs incurred to produce the study. Therefore, the Company is not requesting  
2 separate treatment for the internal costs to produce the study.

3 **Q. IS THE 2018 DISTRIBUTION O&M, SUBJECT TO ADJUSTMENTS YOU**  
4 **IDENTIFIED, A REASONABLE BASIS ON WHICH TO ESTABLISH O&M**  
5 **COSTS FOR THE TEST YEAR?**

6 A. Yes.

7 **Q. ARE THESE O&M EXPENSES REASONABLE AND NECESSARY TO CARRY**  
8 **OUT THE DISTRIBUTION BUSINESS AREA'S KEY FUNCTIONS YOU**  
9 **DESCRIBED ABOVE?**

10 A. Yes. These O&M expenses are necessary to ensure that the Distribution  
11 Business Area is able to deliver safe and reliable electric service to our Colorado  
12 customers.

1 **VII. WILDFIRE MITIGATION**

2 **Q. WHAT IS THE PURPOSE OF THIS SECTION OF YOUR DIRECT**  
3 **TESTIMONY?**

4 A. The purpose of this section of my Direct Testimony is to provide an overview of  
5 the Distribution Business Area's Wildfire Mitigation Plan, including planned  
6 capital additions and O&M costs for 2019, and also address planned capital and  
7 O&M costs for 2020-2023.

8 **Q. PLEASE SUMMARIZE THE COMPANY'S OVERALL REQUEST WITH**  
9 **RESPECT TO ITS DISTRIBUTION WILDFIRE MITIGATION EFFORTS.**

10 A. As discussed in the Direct Testimony of Ms. Trammell, the Company is seeking  
11 recovery of 2019 Distribution capital and O&M costs associated with its updated  
12 Wildfire Mitigation Plan in this rate review, and requesting deferred accounting  
13 treatment for incremental Distribution capital and O&M associated with these  
14 efforts.

15 **Q. WHY IS THE COMPANY MAKING A SPECIFIC REQUEST FOR WILDFIRE**  
16 **MITIGATION?**

17 A. The Colorado region has seen drought and decreased snow pack in the  
18 mountains in recent years. These conditions can increase the risk and effects of  
19 wildfires in areas already prone to risk throughout the hottest and driest months  
20 of the year. Coupled with the Mountain Pine Beetle infestation several years ago  
21 that impacted Public Service's service territory only increases this risk. Public

1 Service owns and operates Distribution assets in high risk areas<sup>6</sup> that include the  
2 foothill and mountainous areas along the Front Range area, in the mountains  
3 along the I-70 corridor, outside of the Grand Junction area, and the more  
4 mountainous areas in the San Luis Valley. In total, the Company estimates that  
5 approximately 70,000 of the 400,000-plus distribution poles that the Company  
6 owns and operates are located within the at-risk area.

7 **Q. WHAT DOES THE COMPANY PROPOSE WITH RESPECT TO**  
8 **DISTRIBUTION'S UPDATED WILDFIRE MITIGATION PROGRAMS IN THIS**  
9 **RATE REVIEW?**

10 A. The Company is currently undertaking activities in its Wildfire Mitigation Plan and  
11 is requesting in this rate review to recover the related O&M and capital costs  
12 incurred in 2019 in the Company's cost of service as this work will continue in the  
13 future. These costs are shown below in Tables CSN-D-4 and CSN-D-5 and 2019  
14 capital additions are included in Attachment CSN-2. The Company has  
15 requested deferred accounting treatment for accelerated wildfire mitigation  
16 activities that the Company plans to perform in 2020-2023. Ms. Trammell  
17 discusses this further in her testimony.

---

<sup>6</sup> As identified by the Colorado State Forest Division at <https://csfs.colostate.edu/wildfire-mitigation/>

1 **Q. WHAT ARE PUBLIC SERVICE'S PROJECTED DISTRIBUTION O&M**  
2 **EXPENSES ASSOCIATED WITH ITS WILDFIRE MITIGATION INITIATIVE IN**  
3 **2019 AND 2020-2023?**

4 A. As shown in Table CSN-D-4 below, the Company is seeking a total of \$8.3  
5 million in incremental Distribution Wildfire Mitigation Plan O&M expense for 2019.  
6 With respect to 2020 through 2023, for which we are seeking deferred  
7 accounting treatment for incremental Distribution Wildfire Mitigation Plan O&M  
8 expense, the Company is forecasting approximately \$11.4 million in 2020, \$8.7  
9 million in 2021, \$9.3 million in 2022, and \$9.4 million in 2023.

1  
2  
3

**Table CSN-D-4:  
 Wildfire Mitigation Programs – Distribution O&M  
 Public Service (Electric)**

<b>Wildfire O&amp;M</b> (Dollars in Millions)					
<b>Category</b>	<b>2019</b>	<b>2020</b>	<b>2021</b>	<b>2022</b>	<b>2023</b>
Corporate	\$0.3	\$0.9	\$0.9	\$0.9	\$0.9
Inspection and Modelling	\$2.7	\$3.6	\$1.7	\$1.7	\$1.7
Protection	\$0.5	\$0.7	\$0.1	\$0.0	\$0.0
Replace	\$4.2	\$4.7	\$4.5	\$5.2	\$4.6
Vegetation	\$0.6	\$1.4	\$1.5	\$1.5	\$2.2
<b>Total*</b>	<b>\$8.3</b>	<b>\$11.4</b>	<b>\$8.7</b>	<b>\$9.3</b>	<b>\$9.4</b>
*There may be differences between the sum of the individual category program amounts and Total amounts due to rounding.					

4 **Q. WHAT ARE PUBLIC SERVICE’S PROJECTED DISTRIBUTION CAPITAL**  
 5 **ADDITIONS ASSOCIATED WITH ITS WILDFIRE MITIGATION PLAN IN 2019**  
 6 **AND 2020-2023?**

7 A. Table CSN-D-5 below contains the Company’s projected Distribution capital  
 8 additions associated with its Wildfire Mitigation Plan for 2019-2023. Attachment  
 9 CSN-2 includes the 2019 capital additions.

1  
2  
3  
**Table CSN-D-5:  
Wildfire Mitigation Programs – Distribution Capital Additions  
Public Service (Electric)**

<b>Wildfire Capital Additions</b> (Dollars in Millions)					
<b>Category</b>	<b>2019</b>	<b>2020</b>	<b>2021</b>	<b>2022</b>	<b>2023</b>
Corporate	\$0.1	\$0.1	\$0.1	\$0.1	\$0.1
Inspection and Modelling	\$0.6	\$0.3	\$0.1	\$0.1	\$0.1
Protection	\$7.9	\$12.2	\$6.2	\$0.0	\$0.0
Replace	\$20.3	\$21.3	\$20.3	\$23.8	\$19.1
<b>Total*</b>	<b>\$29.0</b>	<b>\$33.9</b>	<b>\$26.7</b>	<b>\$23.9</b>	<b>\$19.3</b>
*There may be differences between the sum of the individual category program amounts and Total amounts due to rounding.					

4 **Q. WHAT DO TABLE CSN-D-4 AND TABLE CSN-D-5 SHOW?**

5 A. As I discuss below, many of the Company's wildfire mitigation activities have  
6 historically been completed as part of Distribution's existing programs. The dollar  
7 figures shown in the Tables above, as well as in Attachment CSN-2, reflect  
8 amounts above the Company's normal expenditures for these activities.

9 **Q. WHAT SORT OF WILDFIRE MITIGATION PROGRAMS DOES DISTRIBUTION  
10 MAINTAIN?**

11 A. Distribution programs with respect to the Wildfire Mitigation Plan can generally be  
12 divided into five categories: corporate, inspection and modeling, protection,  
13 replacement, and vegetation management.

14 **Q. DOES THE COMPANY ROUTINELY MAINTAIN THESE PROGRAMS?**

15 A. Yes. The Company historically has maintained several of these programs.  
16 Other programs have been identified and initiated as part of the Company's  
17 Wildfire Mitigation Plan. However, as explained by Ms. Trammell, the Company  
18 believes it would be prudent to accelerate certain activities in the coming years,



1 particularly because the risk of wildfires continues to grow and the Company  
2 needs to ensure it can continue to provide safe and reliable power to the  
3 communities we serve that are in high wildfire risk areas.

4 **Q. PLEASE DESCRIBE THE BUDGET AREAS WITHIN DISTRIBUTION'S**  
5 **CORPORATE PROGRAM.**

6 A. The Corporate program includes \$0.1 million in capital additions and \$0.3 million  
7 in O&M costs in 2019 for following budget areas: Leadership Positions and  
8 Community Relations. These budget areas are described below:

- 9 • *Leadership Positions*: Leadership positions will be responsible to coordinate,  
10 initiate and complete all the Wildfire Mitigation Plan activities.
- 11 • *Community Relations*: Partnership with public agencies, communities, and  
12 the general public are critical for ensuring the success of planned work in  
13 wildfire risk areas.

14 **Q. PLEASE DESCRIBE THE ACTIVITIES WITHIN DISTRIBUTION'S**  
15 **INSPECTION AND MODELING PROGRAMS.**

16 A. The Inspection and Modeling program includes \$0.6 million in capital additions  
17 and \$2.7 million in O&M costs in 2019 for the following activities: pole  
18 inspections, infrared inspections, and wind strength review. The Company's  
19 inspection results inform the activities that the Company will need to undertake  
20 as part of the replacement program.

21 An overview of these activities is provided below:

- 1       • *Pole inspections:* The primary focus for the Company's pole inspection  
2       program for 2019 and 2020 will be in the wildfire risk areas and is an  
3       acceleration of the Company's routine 12-year inspection plan to ensure all  
4       poles in the wildfire area are inspected as soon as possible. For efficiency  
5       purposes, additional poles near the wildfire area will also be inspected in  
6       2019 and 2020. Once all the poles are inspected in the wildfire area, the pole  
7       inspection program is assumed to follow the routine inspection plan but will  
8       account for the results of the accelerated inspections in 2019 and 2020.
- 9       • *Infrared inspections:* Infrared inspections are routinely performed using  
10      thermal imaging technology (infrared) to identify problem areas on distribution  
11      facilities. This inspection allows detection of certain defects that are difficult  
12      or impossible to identify during visual inspection. These inspections will be  
13      more extensive and focused on equipment located in high risk areas and  
14      equipment that is nearing the end of its useful life. Distribution plans are  
15      based on completing infrared inspections in 2019 and 2020. We will evaluate  
16      the need and frequency of future infrared inspections at a later date,  
17      considering the results of the inspections in 2019 and 2020.
- 18      • *Wind strength review:* Wind strength review involves modeling distribution  
19      facilities located within the wildfire risk zones using software to evaluate their  
20      wind strength capacity against high-wind load cases. It is not commonly part  
21      of the Company's routine maintenance activities although it is reviewed as  
22      one of the requirements when defining construction standards for new

1 installations. The planned forecasted spend was developed by funding of an  
2 initial pilot program to determine the characteristics and condition of different  
3 parts of the infrastructure population. The funding forecast is projected based  
4 on a sustained effort to manage resources and address the infrastructure  
5 population over several years.

6 **Q. PLEASE DESCRIBE THE ACTIVITIES WITHIN DISTRIBUTION'S**  
7 **PROTECTION PROGRAM.**

8 A. The Protection Program includes \$7.1 million in capital additions and \$0.5 million  
9 in O&M expense in 2019 and is a comprehensive effort that includes a protection  
10 study of all distribution feeders in the wildfire risk area and upgrades to reclosing  
11 devices such as breakers and reclosers that will leverage technologies being  
12 deployed as part of AGIS which include the Field Area Network and ADMS.

13 An overview of these activities is provided below:

- 14 • *Protection study for feeders:* Modern protection equipment can provide  
15 improved ability to provide reliable service and mitigate the potential for  
16 starting a wildfire. All circuits within the wildfire risk areas are being reviewed  
17 for protection improvements in 2019. Capital work based on this engineering  
18 review is planned to be completed from 2019-2021.
- 19 • *Recloser communications:* Reclosers are pole-mounted remote supervisory  
20 reclosing and switching devices. The recloser communication includes the  
21 cost for communications at each individual recloser device while leveraging

1 the existing deployment of the FAN already planned as part of the AGIS  
2 initiative.

3 • *Substation relay upgrade for remote non-reclosing:* Upgrades to substation  
4 relay equipment will also be required to allow for adaptive protection schemes  
5 that is not possible with more mature relays like electromechanical relays.  
6 The relay upgrades will be identified in coordination with the protection  
7 studies. While these upgrades are similar to those we will implement for  
8 FLISR as part of the AGIS initiative, the upgrades identified here are for  
9 safety purposes, rather than for reliability (which is the purpose of the FLISR-  
10 related upgrades).

11 • *ADMS enhanced circuit breaker functionality:* The ADMS enhanced circuit  
12 breaker functionality is part of the protection upgrade work and will allow for  
13 different protection settings depending on the fire risk. The ADMS enhanced  
14 circuit breaker functionality includes two modules within the ADMS platform  
15 that were not planned as part of the AGIS deployment.

16 • *Design and Installation of New Protective Devices:* The design and  
17 installation of new protective devices will follow the protection reviews and  
18 include such devices as reclosers.

1 **Q. CAN YOU DESCRIBE HOW THE PROTECTION PROGRAM WILL HELP TO**  
2 **MITIGATE THE RISK OF WILDFIRES?**

3 A. Yes. Wildfires related to utility equipment are often caused from sparks from a  
4 failure on a line. Failures can be caused by a number of issues including  
5 vegetation falling into lines, lightning, high winds, animals, failed equipment, and  
6 other types of failures. Protective equipment like reclosers and breakers are  
7 designed to open when a failure is detected and close after a few seconds and  
8 remain closed if the failure is temporary (resulting in a momentary outage for  
9 customers) or open if the failure is permanent requiring a crew to be dispatched  
10 for repairs. The protective equipment program will include upgrades to protective  
11 equipment that for example will allow the Company to modify settings for  
12 reclosers on high wildfire risk days and limit the risk of sparks caused by failures  
13 on lines.

14 **Q. PLEASE DESCRIBE THE ACTIVITIES IN DISTRIBUTION'S REPLACEMENT**  
15 **PROGRAM.**

16 A. The Replacement program includes \$20.3 million in capital additions and \$4.2  
17 million in O&M costs in 2019 for the replacement of equipment that is identified  
18 during the during the inspection process that is described in more detailed above.  
19 An overview of these activities is provided below:

20 • *Pole Replacements:* Pole Replacements are identified through the pole  
21 inspection process and through the wind and condition assessments. The  
22 pole inspection and replacement process is the same process the Company

1 undertakes on an annual basis, but the Company plans to accelerate these  
2 activities in 2019 and 2020 on the nearly 70,000 poles within at risk wildfire  
3 areas. The Company's 2019 plans include the inspection of approximately  
4 40,000 poles in wildfire risk areas and the planned pole replacements are  
5 based on a projected reject rate of 8 percent, meaning the Company  
6 anticipates that it will need to replace 8 percent of inspected poles in the  
7 wildfire risk areas. As noted above, the Company plans to identify an initial  
8 pilot area for wind and condition assessments which will be used to  
9 supplement and enhance information gathered during pole inspections. Pole  
10 replacement activities will continue in 2021 and beyond based on the results  
11 of the Company's inspection and modeling programs.

12 • *Pole Top Reinforcements:* Pole top reinforcements are the replacement of  
13 equipment near the top of the pole, such as cross-arms and switches  
14 identified as needing replacement during pole inspections and infrared  
15 inspections. Identification of pole top degradation historically has been  
16 considered a small reliability risk and minor degradation was not pursued as  
17 aggressively for mitigation. We have learned, however, that pole top  
18 degradation may not only be a small reliability risk, it can also contribute to a  
19 potential ignition. As a result, we are reviewing and accelerating the  
20 replacement of pole top equipment.

21 • *Equipment Upgrades:* Equipment Upgrades include changing out equipment,  
22 primarily fuses and arresters that meet the California Exclusion Criteria. The

1 replacement equipment is superior because it does not spark when operating,  
2 thereby preventing a potential ignition. This equipment replaces industry  
3 standard equipment that is typically used in areas that are not at risk for  
4 wildfires.

5 **Q. CAN YOU DESCRIBE HOW THE REPLACEMENT PROGRAM WILL**  
6 **MITIGATE THE RISK OF A WILDFIRE?**

7 A. Yes. California utilities have identified vegetation contact with lines as the  
8 greatest risk for causing a wildfire. While our vegetation management program  
9 includes activities for minimizing this risk, it is unrealistic we can eliminate this  
10 risk entirely. By pairing vegetation management with the replacement of poles  
11 and the equipment on the tops of poles, we can incorporate industry best  
12 practices aimed at increasing the resiliency of our system and reducing the  
13 likelihood of failure and sparking. Increasing the resiliency of our system also  
14 results in reliability benefits to customers in the form of reducing the risk of  
15 failures and outages on the system.

16 **Q. PLEASE DESCRIBE THE VEGETATION MANAGEMENT PROGRAMS.**

17 A. Vegetation management activities include \$0.6 million in O&M expenses for the  
18 Mountain Hazard Tree Program, pole brushing, and secondary voltage line  
19 clearance. An overview of these activities is provided below:

20 • *Mountain Hazard Tree Program:* The Company's Mountain Hazard Tree  
21 ("MHT") Program involves the mitigation of hazard trees adjacent to both  
22 electric distribution and transmission facilities in areas that have been

1 impacted by the mountain pine beetle epidemic. The enhanced mitigation is  
2 an expansion of the Company's existing program in both scope and scale to  
3 include more primary voltage line miles as well as the addition of patrolling  
4 secondary distribution lines.

5 • *Pole Brushing:* Pole brushing includes maintaining a 10 foot vegetation clear  
6 zone around poles that have overhead devices such as fuses in selected  
7 areas that could emit sparks and ignite a fire should there be an expulsion  
8 fuse operation. The planned activity is based on completing clearing activities  
9 on a four year cycle.

10 • *Secondary Voltage Line Clearance:* Secondary Voltage Line Clearance  
11 expands the Company's current Vegetation Management Guidelines to  
12 include dedicated vegetation inspections and to proactively prune vegetation  
13 around distribution lines with only secondary voltages, street lights and  
14 service lines within the defined zone. Implementing the additional line  
15 segments will be added into the scope of work for Vegetation Management's  
16 planned scope moving forward.

17 **Q. PLEASE DESCRIBE THE PEER REVIEW PROCESS THE COMPANY HAS**  
18 **UNDERTAKEN AS PART OF UPDATING ITS WILDFIRE MITIGATION PLAN.**

19 A. The Company has undertaken several efforts to collaborate with peers and  
20 industry leaders in this space. Most notably, the Company has actively  
21 participated in conferences on this topic and engaged in discussions with  
22 vendors and peer utilities experienced in developing wildfire mitigation strategies.



1           Importantly, we have spent time engaging with representatives from San Diego  
2           Gas & Electric, a utility considered an industry leader for wildfire mitigation, to  
3           identify industry best practices and identify programs appropriate to integrate into  
4           Public Service's wildfire mitigation strategy.

5   **Q.   HAS THE COMPANY, AND WILL THE COMPANY, MANAGE ITS**  
6   **PROJECTED WILDFIRE MITIGATION PLAN COSTS RELATED TO CAPITAL**  
7   **ADDITION AND O&M COSTS IN 2019 TO ENSURE THE FINAL, ACTUAL**  
8   **COSTS ARE REASONABLE AND PRUDENT?**

9   **A.   Yes.**

1 **VIII. AGIS CAPITAL ADDITIONS**

2 **Q. WHAT IS THE PURPOSE OF THIS SECTION OF YOUR DIRECT**  
3 **TESTIMONY?**

4 A. In this section of my Direct Testimony, I support Distribution's capital additions for  
5 which the Company seeks recovery in this rate review with respect to the AGIS  
6 initiative, including actual capital additions placed into service through 2018 as  
7 well as capital additions forecasted for 2019, as introduced by Ms. Trammell and  
8 explained in more detail by Ms. Blair, who supports the Company's cost of  
9 service.

10 **Q. HOW IS THIS SECTION OF YOUR TESTIMONY ORGANIZED?**

11 A. Immediately below, I provide an introduction to each of the AGIS foundational  
12 programs and describe the division of work between the Distribution Business  
13 Area and Business Systems (IT). I also provide an overview of Distribution's  
14 capital additions through 2018 and forecasted 2019 capital additions that are  
15 proposed to be included in the 2018 HTY cost of service.

16 In Sections VIII.A through VIII.F, I discuss each of the foundational  
17 programs in detail. In each Section, I first outline the reasons why Public Service  
18 is implementing the AGIS programs and explain their capabilities. I then discuss  
19 the deployment and implementation of the foundational components of AGIS,  
20 including activities that were carried out from 2016 to 2018, and the  
21 implementation that will continue going forward, consistent with the AGIS CPCN  
22 Settlement.

1 **Q. PLEASE PROVIDE AN INTRODUCTION TO EACH OF THE AGIS**  
2 **FOUNDATIONAL PROGRAMS.**

3 A. Below is an introduction to each of the AGIS foundational programs:

- 4 • *Advanced Distribution Management System* (“ADMS”): ADMS will provide an  
5 integrated operating and decision software and hardware support system to  
6 assist control room, field personnel, and engineers with the monitoring,  
7 control, and optimization of the electric distribution system. It will manage the  
8 complex interaction of Distributed Energy Resources (“DER”), outage events,  
9 feeder switching operations, and the advanced applications utilizing intelligent  
10 field devices, such as IVVO and FLISR, discussed below. ADMS gives  
11 access to real-time and near real-time data to provide all information on  
12 operator console(s) at the control center in an integrated manner, which  
13 means the different operating systems and technologies will communicate  
14 with and update each other in the ADMS platform. ADMS is the fundamental  
15 platform that will utilize the updated data that is being gathered as part of the  
16 GIS project (described below), and manages each of the other AGIS  
17 components described below.
- 18 • *Geospatial Information System* (“GIS”): The GIS provides location  
19 information about all physical assets that make up the Company’s electric  
20 distribution system. The records also include specification information  
21 regarding the physical assets, such as a distribution feeder’s size. While the  
22 Company already has a GIS, the Company is engaging in a data gathering

1 effort to validate and update the information in GIS because the ADMS model  
2 needs accurate information to operate effectively. ADMS will use the GIS'  
3 location and specification information to maintain the as-operated electrical  
4 model and advanced applications.

- 5 • *Advanced Meter Infrastructure* (“AMI”): AMI meters are able to measure and  
6 transmit voltage, current, and power quality data and can act as a “meter as a  
7 sensor,” enabling ADMS to engage in near real-time monitoring of the  
8 distribution system. These meters provide information about customer usage  
9 and will enhance the Company’s ability to send price signals to customers,  
10 allow for new rate structures that will enable customers to manage their  
11 energy usage with near real-time energy usage data available through a  
12 customer web portal, identify outages without customer reporting, respond  
13 efficiently to metering and usage issues, and allow remote service  
14 disconnects and reconnects. AMI meters will replace existing Automated  
15 Meter Reading (“AMR”) meters with more advanced technology to improve  
16 service and reliability.

- 17 • *Field Area Network* (“FAN”): The FAN is the communications network that  
18 will enable communications between the communications infrastructure that  
19 already exists at the Company’s substations, the ADMS, the new AMI meters,  
20 and the new intelligent field devices associated with advanced applications as  
21 described immediately below. The FAN may provide benefits to all AGIS

1 projects, but is designed and built according to the needs of various specific  
2 components, and each has different communication network requirements.

- 3 • *Advanced Applications that Utilize Intelligent Field Devices:* The following  
4 advanced applications and associated field devices will support a more  
5 advanced grid:

- 6 • *Integrated Volt-VAr Optimization (“IVVO”)* is an application that automates  
7 and optimizes the operation of the distribution voltage regulating and VAr  
8 control devices to reduce electrical losses, electric demand, and energy  
9 consumption, and provides increased distribution system injection  
10 capacity to host DER.

- 11 • *Fault Location Isolation and Service Restoration (“FLISR”)* uses software  
12 and automated switching devices to decrease the duration of, and number  
13 of customers affected by, any individual outage. The automated switching  
14 devices detect feeder mainline faults, isolate the fault by opening section  
15 switches, and restore power to un-faulted sections by closing tie switches  
16 to adjacent feeders as necessary.

- 17 • *Fault Location Prediction (“FLP”)*, is a subset application of FLISR that  
18 leverages sensor data from field devices to locate a faulted section of a  
19 feeder line and reduce patrol times needed to physically locate the fault.

1 **Q. WHAT KINDS OF ACTIVITIES WILL THE DISTRIBUTION BUSINESS AREA**  
2 **PERFORM TO IMPLEMENT THE AGIS FOUNDATIONAL PROGRAMS?**

3 A. At a high level, the work that the Distribution Business Area will undertake falls  
4 into four primary categories: (1) installing field devices (advanced meters, and  
5 devices to implement IVVO, FLISR, FLP); (2) data collection (ADMS/GIS); (3)  
6 determining appropriate business processes to manage the system; and (4)  
7 determining employees' roles and responsibilities in implementing and operating  
8 the new programs that are part of the AGIS initiative. The last two categories I  
9 identified (3 and 4) are both part of Program and Change Management to ensure  
10 a successful implementation, which are discussed separately in Section VIII.F  
11 and comprise a part of each AGIS project.

12 **Q. HOW IS THE COMPANY SUPPORTING ITS AGIS COSTS IN THIS RATE**  
13 **REVIEW FILING?**

14 A. AGIS costs are incurred by both the Distribution Business Area and the Business  
15 Systems (IT) organization for each of the AGIS programs. In the remainder of  
16 my testimony, I describe each of the AGIS foundational programs in more detail  
17 and explain Distribution's work to forecast and implement the AGIS projects

18 I provide the primary support for the costs and implementation related to  
19 the GIS data collection effort for ADMS, the AMI meters, the procurement and  
20 installation of pole-mounted FAN devices, the advanced applications utilizing  
21 intelligent field devices (i.e., IVVO, FLISR and FLP), and additional elements of

1 the AGIS implementation process including Program and Change Management  
2 efforts.

3 Business Systems has primary responsibility for the ADMS IT  
4 components, the IT integration of AMI (but not the meters themselves) and the  
5 AMI head-end application, the IT integration and deployment of the FAN, and the  
6 forecast development for the FAN. As explained by Mr. Harkness, Business  
7 Systems is the centralized IT organization for the Xcel Energy operating  
8 companies and provides technology services to support all aspects of the  
9 operations of the Xcel Energy OpCos, including Public Service. For this rate  
10 review, Mr. Harkness provides the primary support for the costs related to the  
11 components of the AGIS programs identified above.

12 In summary, Mr. Harkness and I support the costs and forecasts of the  
13 AGIS components as follows:

1

**Table CSN-D-6: AGIS Program Witness Support**

<b>AGIS Foundational Program</b>	<b>Component</b>	<b>Witness</b>
ADMS / GIS	System Development	Harkness
	GIS Data Collection	Nickell
AMI	IT Integration	Harkness
	Head end application	Harkness
	Meters and deployment	Nickell
FAN	IT Integration and deployment	Harkness
	Procurement and installation of pole-mounted devices	Nickell
IVVO	Application deployment	Harkness
	Advanced application and field devices	Nickell
FLISR / FLP	Application deployment	Harkness
	Advanced application and field devices	Nickell

2 **Q. WHAT TYPES OF EXPENDITURES FOR AGIS ARE CLASSIFIED AS**  
 3 **CAPITAL COSTS?**

4 A. Capital costs include expenses for new equipment like meters and intelligent field  
 5 devices, costs to modify existing equipment, and related installation and labor  
 6 costs. This is an illustrative list, but it is not exhaustive.

7 **Q. WHAT TYPES OF CAPITAL COSTS IS DISTRIBUTION INCURRING TO**  
 8 **IMPLEMENT THE AGIS PROJECTS?**

9 A. Capital costs Distribution is incurring to implement AGIS include the capital cost  
 10 of installing additional equipment on the distribution system for IVVO, FLISR and  
 11 FLP, and the capital costs to install AMI meters (including the costs of the  
 12 devices, meters, and equipment themselves), the costs required to make capital  
 13 modifications to equipment in distribution substations and at various points on the



1 electric distribution system (“make-ready work”), and the costs to collect and  
 2 build the GIS data additions required to operate ADMS. Together, these costs  
 3 include equipment and device costs, labor, contractor and vendor services,  
 4 transportation, material and stores expenses, permitting, traffic control,  
 5 restoration, disposal costs, etc.

6 **Q. WHAT ARE DISTRIBUTION’S ACTUAL AND PROJECTED CAPITAL COSTS**  
 7 **FOR AGIS IMPLEMENTATION THAT THE COMPANY SEEKS TO RECOVER**  
 8 **IN THIS RATE REVIEW?**

9 A. Distribution’s AGIS capital additions that Public Service seeks to recover in this  
 10 rate review, are shown below in Table CSN-D-7 below.

11 **Table CSN-D-7:**  
 12 **AGIS Distribution - Capital Additions**  
 13 **(Total Company)**

14 (Dollars in Millions)

<b>AGIS Program</b>	<b>2016</b>	<b>2017</b>	<b>2018</b>	<b>2019</b>
ADMS	0.0	0.0	11.7	8.6
AMI	0.0	0.0	0.2	10.1
FAN	0.1	0.1	0.0	11.1
FLISR	2.0	3.2	(4.0)	17.4
IVVO	0.0	0.0	0.6	24.2
<b>Total*</b>	<b>2.1</b>	<b>3.2</b>	<b>8.5</b>	<b>71.4</b>
*There may be differences between the sum of the individual AGIS program amounts and Total amounts due to rounding.				

15 Distribution’s AGIS-related capital additions are also set forth in Attachments  
 16 CSN-1 and CSN-2. I provide additional support for the capital costs, organized  
 17 by AGIS component, in Sections VIII.A-VIII.F of my testimony, below.

1 **Q. HOW DO THE IVVO, AMI, AND FAN COSTS COMPARE TO THE AGIS CPCN**  
2 **SETTLEMENT APPROVED IN PROCEEDING NO. 16A-0588E?**

3 A. The Company's deployment costs are consistent with the AGIS CPCN  
4 Settlement amounts, and Recommended Decision R18-0590 approving the  
5 uncontested (amended) application in Proceeding No. 18A-0194E, which  
6 includes an additional \$2.8 million to implement an AMI network that includes  
7 HAN capabilities.

8 **Q. ARE DISTRIBUTION'S CAPITAL COSTS PRESENTED ABOVE CONSISTENT**  
9 **WITH THE INFORMATION PROVIDED IN PUBLIC SERVICE'S COMPLIANCE**  
10 **FILINGS IN PROCEEDING NO. 16A-0588E?**

11 A. The actual capital costs, which include the costs incurred through 2018, are  
12 consistent with the cost information filed by the Company in its Annual Actuals  
13 Report for 2017 filed in May 2018 in Proceeding No. 16A-0588E.

14 Distribution's capital costs forecasted for 2019 are slightly lower than was  
15 reported by Public Service in the Grid CPCN 2019 Forecast Report filed in  
16 October 2018 in Proceeding No. 16A-0588E due to some adjustments in the  
17 timeline of implementation activities for AMI and IVVO.

18 **Q. IS THE COMPANY INSTITUTING CONTROLS TO ENSURE AGIS**  
19 **IMPLEMENTATION IS CONDUCTED EFFECTIVELY, AND WITHIN**  
20 **FORECAST?**

21 A. Yes. The AGIS program has established standard program governance  
22 processes, which were developed based on established Xcel Energy Enterprise

1 methods. Project Management Office (“PMO”) services include management of  
2 processes, governance structures, metrics and reporting. The core PMO  
3 function provides Program Governance which includes Program Management,  
4 Resource Management, and Financial Management. A dedicated team has  
5 been established to develop, manage and ensure quality and compliance to all  
6 governance processes.

7 **Q. HOW DOES THE AGIS PROGRAM ENSURE EFFECTIVE COST**  
8 **CONTAINMENT RELATED TO THE AGIS PROJECTS?**

9 A. The Company’s AGIS governance includes Program Management, Resource  
10 Management, and Financial Management. Program Management includes  
11 Scope Change, Risk/Issue Management, and Work and Schedule Management.  
12 Resource Management includes on-boarding and off-boarding of AGIS  
13 personnel, resource demand and capacity planning, and resource forecasting.  
14 Financial Management includes financial forecasting, budget management, cost  
15 benefit analysis, and contract management. Controls are established to ensure  
16 that processes with appropriate approval levels are adhered to.

17 **A. Advanced Distribution Management System (ADMS) and Geospatial**  
18 **Information System (GIS)**

19 **1. ADMS and GIS Functions and Capabilities**

20 **Q. WHAT IS THE ADMS?**

21 A. As mentioned above, ADMS is a foundational system that consists of a collection  
22 of hardware and software applications designed to monitor and control the entire  
23 electric distribution system safely, efficiently, and reliably. An ADMS acts as a

1 centralized decision support system that assists the control room, field operating  
2 personnel, and engineers with the monitoring, control, and optimization of the  
3 electric distribution system. The multiple applications within ADMS will constitute  
4 a single system that will enable the optimization of each application by using one  
5 operating model and the same power flow measurements and calculations.

6 **Q. WHAT IS GIS?**

7 A. A GIS is a system or program that captures, stores and manages geographic  
8 data / geographically referenced information. For Public Service, GIS is, in  
9 essence, a digital map of the Company's distribution system. GIS data is critical  
10 to the ADMS to provide location and specification information for all of the  
11 physical assets that make up the distribution system.

12 **Q. HOW WILL ADMS IMPROVE THE WAY THE COMPANY CURRENTLY**  
13 **MONITORS THE DISTRIBUTION SYSTEM?**

14 A. ADMS will enable access to real-time and near real-time data to provide all  
15 information on operator console(s) at the control center in an integrated manner  
16 and make adjustments for real-time grid conditions and topology that are  
17 impacted by each application. Some of the Company's key objectives for ADMS  
18 include optimizing switching sequences, improving the distribution system's  
19 reliability and quality of service in terms of reducing outages and minimizing  
20 outage time (through FLISR), maintaining acceptable voltage levels on the  
21 system (through IVVO), and maintaining awareness of DER impacts to power  
22 flow on the grid.

1 **Q. HOW WILL ADMS ACHIEVE THESE IMPROVEMENTS?**

2 A. ADMS will utilize an enhanced distribution grid model that will include  
3 substations, feeders, taps, and services in one user interface, to more accurately  
4 represent the entire distribution grid. Because GIS will provide the nominal  
5 geospatial electrical model to ADMS, accuracy of the GIS model including  
6 impedance data will be essential, as this data will improve the model when  
7 operating advanced applications like IVVO and FLISR. ADMS will maintain the  
8 as-operated GIS electrical model and advanced applications in near real-time.  
9 This model will provide the Company with greater visibility into the distribution  
10 system and provide information about the system at a more granular level.  
11 Historically, the Company has not had the ability to track the level of detail that  
12 ADMS will require in order to operate the distribution system effectively.  
13 Therefore, the Company is in the process of updating all of its physical asset  
14 records to ensure that the information available complies with the necessary level  
15 of detail needed for ADMS. In addition, Public Service's ADMS will integrate  
16 existing Supervisory Control and Data Acquisition ("SCADA") system  
17 measurements with the enhanced model. This will allow the Company to monitor  
18 and control power flow from substations to the edge of the grid, enabling multiple  
19 grid performance objectives.

1 **Q. HOW IS THE COMPANY ASSESSING THE LEVEL OF GIS DATA NEEDED IN**  
2 **ORDER TO EFFICIENTLY OPERATE ADMS?**

3 A. The Company has entered in to a Technology Partnering Agreement with the  
4 National Renewable Energy Laboratory (“NREL”) to assist in analyzing what  
5 specific GIS data is needed to enable ADMS functionality. As a member of the  
6 Department of Energy sponsored ADMS “testbed”, NREL maintains a  
7 demonstration laboratory that will allow the Company to model how ADMS will  
8 interact with various levels of data. This partnership, which also includes  
9 Schneider Electric (the provider of Public Service’s ADMS platform), will allow the  
10 Company to efficiently collect the data necessary to operate the system  
11 effectively and enable the AGIS program functions. NREL has provided a  
12 preliminary report of its findings and the Company is reviewing the report and  
13 assessing next steps.

14 **Q. PLEASE DESCRIBE THE FUNCTIONS OF ADMS.**

15 A. ADMS will have core applications, which will make up the foundation of ADMS,  
16 as well as advanced applications. The core applications include distribution  
17 network modeling, network topology processor, impedance calculation,  
18 unbalanced load allocation, unbalanced load flow, state estimation, and  
19 distribution SCADA. These applications provide the basis for running load flow  
20 and state estimation on the distribution system providing near real-time  
21 calculations of the state of the network including factors such as voltages,  
22 currents, real and reactive power, amps, voltage drops, and losses.

1           The ADMS advanced applications will utilize the core applications and  
2 provide additional capability. Public Service will utilize two such advanced  
3 applications: IVVO and FLISR (and FLP). These applications will rely on  
4 accurate power flow calculations to determine the power flow at points on the  
5 grid where sensor information does not exist. For example, if there are no  
6 sensors on a feeder, the Unbalanced Load Flow core application will apply power  
7 flow measurements taken at the substation to calculate power flow throughout  
8 the feeder.

9           Although sensors are not a component of ADMS itself, ADMS will utilize  
10 sensor and equipment information, located at strategic points on the grid, to  
11 continuously improve upon the power flow calculations made by the power flow  
12 application. For example, AMI meters will measure and transmit voltage, current,  
13 and power quality data and can act as a “meter as sensor” providing near real-  
14 time monitoring information to ADMS. Where sensor data is available, power  
15 flow results will be refined and utilized through the ADMS application.

16 **Q. CAN YOU PROVIDE EXAMPLES OF HOW ADMS WILL PROVIDE THE**  
17 **CAPABILITY TO ENABLE OTHER APPLICATIONS AND OBJECTIVES?**

18 A. Yes, the IVVO and FLISR functions (discussed in more detail below) will be  
19 applied to the same feeders in a given portion of the distribution grid. FLISR will  
20 facilitate fault isolation and service restoration activities. IVVO technology will be  
21 able to manage voltage and power quality objectives both before and after fault  
22 isolation and service restoration activities are carried out by automatic FLISR and

1 manual switching operations. IVVO and FLISR systems could be implemented  
2 independently, but with reduced efficiency. By implementing IVVO and FLISR in  
3 ADMS, the applications are integrated and coordinated to realize the full benefits  
4 of each application.

5 **Q. DO YOU FORESEE FURTHER USES FOR ADMS IN THE FUTURE?**

6 A. Yes. ADMS will provide a dynamic model and real-time power flow information  
7 that will facilitate increased penetration and integration of DERs, energy storage,  
8 integration of micro-grids, and future customer choice. The need for ADMS  
9 arose, at least in part, because of the increase in two-way power flow resulting  
10 from the growth of DERs, including renewable resources, on Public Service's  
11 distribution system. The visibility enabled by ADMS will provide the Company  
12 with information about these resources and their impacts that will be necessary  
13 to manage the system. The ADMS platform's ability to monitor, incorporate, and  
14 manage the higher penetration levels of DER, storage, and micro-grids, will also  
15 enable ADMS to implement actions to limit the potential negative impacts of  
16 these technologies on traditional electric customers, such as higher-than-  
17 necessary voltage that results from greater penetrations of solar on the  
18 distribution feeders. As DER penetration levels continue to rise, and as new  
19 storage and micro-grid technologies emerge and need to be connected to the  
20 grid, other ADMS applications will be necessary to study and manage the  
21 behavior of the grid to ensure maintained reliability.



1                   **2. ADMS and GIS Implementation and Costs**

2   **Q.   WHAT WILL BE THE PHYSICAL COMPONENTS OF ADMS?**

3   A.   ADMS will be composed of hardware, software, distribution SCADA, and an  
4       impedance model, which is an accurate electrical representation of the  
5       distribution grid, including substations, core, and advanced applications.

6   **Q.   WHAT WORK IS DISTRIBUTION UNDERTAKING TO IMPLEMENT THE  
7       ADMS AND GIS PROJECT?**

8   A.   Although Distribution will be the business area that utilizes ADMS, Business  
9       Systems is responsible for the implementation of ADMS—building the ADMS  
10      model, including hardware, software, and Information Technology integration—  
11      and its ongoing maintenance, as discussed by Mr. Harkness.

12           Distribution is involved in three components of ADMS implementation.  
13       First, the GIS data collection effort, for which Distribution has primarily  
14       responsibility, will require collecting (a) data that will validate the physical  
15       characteristics of the current system, and (b) additional data that defines the  
16       electrical characteristics necessary to enable the ADMS model. The second  
17       category includes implementation of select intelligent field devices to test ADMS  
18       and ensure it has the necessary operating information. Third, all components of  
19       AGIS will have Program and Change Management efforts. I discuss the work  
20       that will be done related to Program and Change Management in Section VIII.F  
21       below.

1 **Q. WHAT WORK WILL DISTRIBUTION COMPLETE REGARDING THE GIS**  
2 **DATA COLLECTION EFFORT TO ENABLE THE ADMS MODEL?**

3 A. The Company is currently validating asset information pertaining to physical  
4 characteristics of the system. Since the ADMS is dependent on a robust dataset,  
5 Distribution will leverage system and data knowledge and confirm the accuracy  
6 and completeness of the electric distribution grid model. This is accomplished by  
7 verifying the information contained in the corporate GIS via the performance of a  
8 physical data verification and capture effort to determine the level of readiness to  
9 support the ADMS application. Distribution will also ensure the representations  
10 of customer load profiles and generation are accurate to meet the needs of  
11 advanced applications. Finally, we will use SCADA development for new device  
12 configuration requirements and alignment with current SCADA systems.

13 **Q. PLEASE PROVIDE SOME EXAMPLES OF THE DATA DISTRIBUTION WILL**  
14 **COLLECT.**

15 A. Examples of the data we will collect include the size of distribution system wiring,  
16 the size and location of equipment such as transformers, switches, poles,  
17 phasing and connectivity, and device control settings. This process validates the  
18 various data attributes contained in the corporate GIS system. As a result, the  
19 physical plant and the electrically connected model are reflective of one another.

20 **Q. HOW IS THE COMPANY GATHERING THE GIS DATA?**

21 A. Public Service has selected Cyient, a third-party vendor, to complete the work of  
22 collecting the GIS data. Cyient was selected through a competitive Request for

1 Proposals (“RFP”) process. Specifically, Cyient will perform field verification of  
2 electric distribution assets. This involves confirming information contained in the  
3 corporate GIS platform, verifying equipment attributes and documenting  
4 differences. Information is then quality control checked prior to updating the  
5 corporate GIS, which interfaces with the ADMS to support grid optimization  
6 analysis. The Company has completed the data gathering process for  
7 approximately 55 percent of its distribution feeders. The Company anticipates  
8 completing the data gathering in the fourth quarter of 2021.

9 **Q. HOW WILL DISTRIBUTION TEST THE ADMS SYSTEM?**

10 A. Because ADMS is a foundational system that will control the advanced  
11 applications, ADMS must be functional upon deployment of the field devices and  
12 advanced meters. To ensure that ADMS is operating efficiently and effectively,  
13 the Company must complete end-to-end testing of the system, including with  
14 some intelligent field devices that will be utilized by the advanced applications  
15 like IVVO and FLISR. By deploying some of these devices for testing, Public  
16 Service’s Distribution Business Area will be able to provide and validate use  
17 cases and test cases so we can ensure the software performs consistently with  
18 our needs for managing the electric distribution grid. These devices are not  
19 temporary and will be used as part of the intelligent field device deployment. In  
20 addition, the 2019 capital additions for ADMS reflect costs for the Company’s  
21 testing lab, which performs testing of devices to implement the AGIS programs,  
22 but that will not be installed in the field. We will also use this testing to configure

1 and maintain ADMS performance with the substations and advanced  
2 applications. We will also participate in software testing to validate that the  
3 software is able to manage the electric distribution grid and deliver the  
4 application performance required to meet corporate commitments.

5 **Q. PLEASE PROVIDE DISCUSS THE IMPLEMENTATION OF ADMS ITSELF.**


6 A. Public Service began the design and implementation of ADMS in the second  
7 quarter of 2016, and expects ADMS to be operational later in 2019. ADMS  
8 implementation will occur in three stages. The first involves standing up the  
9 ADMS software which will permit the IVVO advanced application to be enabled.  
10 In the next phase, ADMS will “go live” at the control center with respect to a  
11 limited number of feeders and field devices later in 2019. The third phase will  
12 enable the IVVO application on additional feeders and continues through 2022.

13 Although the primary ADMS work, including work related to the hardware,  
14 software and labor associated with the design and build of the ADMS system and  
15 interfaces, is conducted by Business Systems, and described in detail by Mr.  
16 Harkness, Distribution and Business Systems have conducted their ADMS  
17 implementation activities in partnership with each other.

18 Figure CSN-D-2 shows a timeline of ADMS implementation activities.

1

**Figure CSN-D-2**



2 **Q. WHAT ARE THE PRIMARY ELEMENTS OF THE DISTRIBUTION BUSINESS**  
 3 **AREA’S ADMS AND GIS CAPITAL FORECAST?**

4 A. The primary components of the Distribution Business Area’s ADMS and GIS  
 5 capital forecast, shown in Table CSN-D-7 and Attachments CSN-1 and CSN-2,  
 6 are: (1) field audit of distribution pole data and data collection, and (2) substation  
 7 data collection and loading.

8 **Q. HOW DID THE DISTRIBUTION BUSINESS AREA DERIVE THE FORECAST**  
 9 **FOR THESE ACTIVITIES?**

10 A. Two vendors (Cyient and Ramtech) participated in a data collection pilot effort in  
 11 2017. Their RFP responses provided expected costs for data collection by pole  
 12 and substation. The Company used those per unit costs and extrapolated them  
 13 using greater Public Service system information.

14 In addition, in order to create a project forecast for the GIS collection  
 15 activity, the Company engaged in scoping activities:

- 1 • Conducting a gap analysis to determine what additional information was  
2 needed in the Company's GIS data model for ADMS to run successfully.
- 3 • Identification of changes required to the GIS data model to support ADMS.
- 4 • Identification of data to be captured from other sources (such as substation  
5 equipment databases) and how this will be provided to ADMS.
- 6 • Assessing the quality of data already held in the GIS and external sources  
7 and determination whether additional data cleanup activities are required.
- 8 • Identification of data attributes that are to be field verified and updated in the  
9 GIS.

10 **Q. CAN YOU PROVIDE ADDITIONAL DETAIL REGARDING THE**  
11 **DEVELOPMENT OF THE DISTRIBUTION BUSINESS AREA'S ADMS COST**  
12 **FORECAST?**

13 A. Yes. In general, the processes used to develop the ADMS cost forecasts were  
14 the same for both Distribution and Business Systems. Prior to beginning the  
15 sourcing process, in 2013 a cross-functional Xcel Energy team began identifying  
16 and visiting United States utilities that had either implemented, or were in the  
17 process of implementing, an ADMS. These site visits provided information that  
18 was used in the internal planning process. Based on this benchmarking effort,  
19 an RFP was issued in 2014 and an extensive sourcing selection process was  
20 utilized to determine the successful vendor—Schneider Electric.

21 In 2015 the Company initiated a "blue print and design" phase with the  
22 selected ADMS vendor and other key business partners to develop extensive

1 business and integration requirements for the project. This effort was used to  
2 negotiate key contracts with the vendor. To assist in the negotiation process, the  
3 Company hired consulting firm ICG to act as a trusted advisor due to ICG's  
4 detailed industry knowledge of ADMS to ensure that contract terms and  
5 deliverables were reasonable and appropriate. In 2016, following contract  
6 negotiations, the Company and the successful vendor, Schneider Electric, began  
7 detailed design of the project and completed the design in April of 2017. Based  
8 on this extensive effort, detailed budgets were developed and updated in June of  
9 2016. After detailed design, Distribution has supported the implementation and  
10 functionality testing of ADMS, which has included testing and commissioning of  
11 FLISR and IVVO devices, verifying functionality of load flow and state estimation,  
12 and commencement of testing IVVO and FLISR algorithms in support of ADMS.

13 **Q. WILL ADMS AND THE GIS PROJECT PROVIDE BENEFITS TO THE**  
14 **COMPANY AND ITS CUSTOMERS?**

15 A. Yes. Enhancing the Company's GIS and implementing ADMS by itself may not  
16 provide direct benefits to customers that they can see. However, as the  
17 centralized system it enables these programs to work with the applications that  
18 provide customer-facing benefits.

19 **Q. WHY ARE THE DISTRIBUTION BUSINESS AREA'S ADMS AND GIS COSTS**  
20 **REASONABLE FOR CUSTOMERS TO SUPPORT?**

21 A. Of the various data elements required to support the ADMS, GIS is the most  
22 critical data source. For ADMS to perform its calculations and provide accurate

1 results, the GIS model must be enhanced. The calculations will drive the  
2 operation of IVVO and FLISR, and provide a means of tracking the FAN assets.  
3 These are reasonable and necessary expenses to enable the ADMS capabilities,  
4 which in turn provide the customer benefits.

5 Further, the Company has gone through an extensive process to select an  
6 ADMS vendor that will be able to deliver the overall business requirements that  
7 are necessary to operate a modern electric distribution grid. ADMS is not only a  
8 foundational tool, it is a critical part—the “engine”—of the overall package of tools  
9 necessary to deliver reliable energy efficiency measures and to enable the  
10 integration of increasing quantities of DERs without compromising reliability and  
11 power quality. Finally, the forecasts for ADMS were also developed using the  
12 Company’s thorough and extensive process in which information was collected  
13 from other utilities, industry experts, consultants, and a rigorous sourcing  
14 process.

15 **B. Advanced Metering Infrastructure (AMI)**

16 **1. AMI Functions and Capabilities**

17 **Q. WHAT IS AMI?**

18 A. AMI is an integrated system of advanced meters, communications networks, and  
19 data management systems that enables two-way communication between the  
20 utility’s business data systems and customer meters. Advanced meters are the  
21 key endpoint component of an AMI system that measures, stores, and transmits  
22 metering quantities, including energy usage information at customer locations.



1 **Q. WHY IS PUBLIC SERVICE TRANSITIONING TO AMI TECHNOLOGY?**

2 A. As detailed in our approved CPCN, advanced meters can provide substantial  
3 near real-time data that can be used to improve the Company's ability to monitor,  
4 operate, and maintain the distribution grid. Advanced meters can be used to  
5 verify power outages and service restoration, functionality the Company currently  
6 does not have. Improved monitoring can lead to improved outage response,  
7 proper protection system analysis and ultimately reduce outages. Advanced  
8 meters can also provide improved voltage monitoring and management, support  
9 better load studies and analysis resulting in improved planning and design, and  
10 be used to support additional systems such as an ADMS with applications like  
11 IVVO that will promote energy efficiency and peak shaving. The functionality  
12 enabled by advanced meters will also be able to support new rate designs that  
13 cannot be supported by the Company's current AMR meters.

14 **Q. HOW WILL ADVANCED METERS WORK WITH THE OTHER COMPONENTS**  
15 **OF THE AGIS INITIATIVE?**

16 A. The advanced meters will collect the data that will be communicated through the  
17 FAN, which I describe in more detail below, to the AMI head-end system which  
18 will have an interface to ADMS to allow the Company to more efficiently manage  
19 the distribution system.

1                   **2. AMI Implementation, Costs, and Benefits**

2   **Q. PLEASE PROVIDE AN OVERVIEW OF THE PROCESS THE COMPANY HAS**  
3   **UNDERTAKEN TO IMPLEMENT AMI.**

4   A. The Company began detailed planning for AMI in 2016 and issued a Request for  
5   Information and Pricing (“RFx”) with respect to advanced meters and the AMI  
6   head-end system (and the FAN’s WiSUN mesh network) in 2016. The Company  
7   selected a vendor and contractor for the AMI head-end and the mesh network  
8   (i.e., the communication component), and issued a separate RFP to select the  
9   meter vendor. The Company is currently in negotiations to finalize a single meter  
10   vendor.

11               Distribution and Business Systems will work together to manage the  
12   logistics for AMI installation and removal of existing AMR meters. I provide an  
13   overview of the AMI development and the AMI meter vendor selection process  
14   and forecasting. Company witness Mr. Harkness discusses AMI head-end and  
15   integration development and provides support for the associated costs.

16   **Q. PLEASE DESCRIBE THE WORK THE DISTRIBUTION BUSINESS AREA IS**  
17   **PERFORMING TO SUPPORT AMI IMPLEMENTATION.**

18   A. In 2017, Distribution and Business Systems participated in contract awards (from  
19   RFPs) for AMI system integration and for a network vendor to support WiSUN  
20   (the mesh network portion of the FAN that will utilize the advanced meters’  
21   communications modules). We also commenced design and planning processes  
22   for AMI and began qualification of various advanced meters as part of the AMI

1 meter RFP process. Distribution also began to develop its business processes  
2 for AMI and started its Program Management efforts.

3 In 2018, we engaged in detailed meter installation planning, completed the  
4 advanced meter testing qualification testing, and started contract negotiations for  
5 the advanced meters and deployment. The Distribution Business Area has  
6 continued to work on its business processes. No AMI components were placed  
7 in service in 2017 or 2018.

1 **Q. PLEASE DESCRIBE THE WORK THE DISTRIBUTION BUSINESS AREA**  
2 **WILL UNDERTAKE GOING FORWARD TO SUPPORT AMI**  
3 **IMPLEMENTATION, PARTICULARLY METER DEPLOYMENT.**

4 A. Public Service plans to deploy approximately 1.6 million advanced meters in  
5 Colorado between 2019 and 2024. The first meters are planned to be installed in  
6 2019, in conjunction with the implementation of the WiSUN mesh network that  
7 will support IVVO. The Distribution Business Area will be primarily responsible  
8 for the deployment of advanced meters. Meter deployment includes AMI  
9 hardware evaluation, testing, acquisition, configuration, and the physical  
10 deployment of electric meter assets. The AMI deployment also includes  
11 hardware for customer HAN capabilities.

12 In 2019, the Distribution Business Area will continue testing the AMI  
13 meters and data for operational use, prepare for the meter acquisition, and begin  
14 initial deployment. We will continue to conduct additional testing of meters for  
15 both electric distribution and customer operational requirements. Testing covers  
16 meter specifications (including the meters' network information communication  
17 card and internal disconnect switch), as well as the ability of the meters to  
18 integrate with products, applications, and platforms involved with AMI.

19 Distribution will coordinate closely with the meter vendor and engage in  
20 joint planning and scheduling processes. We will also help support the process  
21 for the removal, retirement, and disposal of the non-AMI meters, which will be  
22 performed by the meter installation vendor. The Company is also developing

1 business tools to enable electric meter communications with customers' HANs,  
2 and will develop customer communication plans to support the mass meter  
3 rollout that complements our wider corporate strategy for the overall customer  
4 engagement experience.

5 **Q. WHAT ARE THE PRIMARY COMPONENTS OF DISTRIBUTION'S AMI**  
6 **CAPITAL FORECAST?**

7 A. The primary components of the Distribution's AMI capital forecast, shown in  
8 Table CSN-D-7 and Attachments CSN-1 and CSN-2, are: (1) meters, (2) meter  
9 installation, (3) vendor project management, and (4) AMI Operations (internal  
10 and external personnel). It should be noted that costs related to Change  
11 Management constitute a portion of each AGIS program's forecast. Change  
12 Management is discussed separately below. Lastly, the AMI forecast includes  
13 HAN cost estimates, consistent with the AGIS CPCN Settlement.

14 **Q. HOW DID DISTRIBUTION DERIVE ITS CAPITAL FORECAST FOR THE AMI**  
15 **METER COSTS?**

16 A. The forecast for the meter costs was developed from the information provided  
17 from each vendor from its RFX for residential and commercial type meters. Meter  
18 costs were separated into two categories—residential and commercial. The total  
19 price for meters for each category was divided by the number of meters in that  
20 category to arrive at an average per-meter cost per category for each vendor,  
21 and the results of each category from each vendor were then averaged to arrive  
22 at an overall estimated unit cost.

1 **Q. HOW DID DISTRIBUTION DERIVE ITS CAPITAL FORECAST FOR AMI**  
2 **METER INSTALLATION?**

3 A. The forecast for meter installation was developed from the average cost provided  
4 from the vendors that responded to the Company's RFX. Because responding  
5 vendors did not provide sufficient detail to determine if they met the Company's  
6 required installation procedures for commercial meters, the Company's present  
7 contractor installation costs for commercial meters were weighted proportionally  
8 to develop a per unit commercial meter installation cost. The Company  
9 developed a weighted average of residential and commercial meter installation  
10 cost per meter for its overall meter installation forecast.

11 **Q. HOW DID DISTRIBUTION DERIVE ITS CAPITAL FORECAST FOR AMI**  
12 **VENDOR PROJECT MANAGEMENT?**

13 A. The forecast for AMI vendor project management was developed from the  
14 average pricing provided by respondents to the RFX. In addition to project  
15 management, this cost estimate includes training, integration assistance, and  
16 system testing.

17 **Q. HOW DID DISTRIBUTION DERIVE ITS CAPITAL FORECAST FOR AMI**  
18 **OPERATIONS RELATED TO INTERNAL AND EXTERNAL PERSONNEL?**

19 A. Internal personnel included roles such as AMI Analyst, Billing Analyst, Project  
20 Operations Manager, Meter Supervision, Meter Engineering, and Inventory  
21 Analyst. The forecast for these positions was developed using average internal  
22 wage scales for these positions and estimating when the roles would be needed

1 throughout the AMI deployment. External personnel include the roles of Billing  
2 Contractor, Scheduling Contractor, and Temporary Office Contractor. The  
3 forecast for these positions was also developed using average costs for these  
4 positions and estimating when the roles would be needed throughout the AMI  
5 deployment. Additionally, external personnel costs include an Electrical  
6 Contractor and a General Repair Contractor. The forecast for these is an  
7 estimate of costs that we may incur as a result of the Company needing to repair  
8 customer property that may be damaged during the meter exchange.

9 **Q. WHY ARE DISTRIBUTION'S AMI COSTS REASONABLE FOR CUSTOMERS**  
10 **TO SUPPORT?**

11 A. AMI is a foundational component of AGIS. As discussed above, AGIS is a long-  
12 term strategic initiative to transform our electrical distribution system to enhance  
13 security, efficiency, and reliability, to safely integrate more DERs, including those  
14 that are customer owned, and to enable improved customer products and  
15 services. The AMI forecast put forward is reasonable in enabling technologies  
16 that improve customer products and services.

17 **Q. ARE ANY COSTS INCLUDED IN THE REQUEST YOU ARE SUPPORTING**  
18 **FOR AMI METERS BEYOND THOSE INSTALLED FOR THE PURPOSES OF**  
19 **IVVO?**

20 A. No. The costs, both capital and O&M, that I am supporting in this proceeding  
21 reflect only those costs associated with the 2019 meter deployments for the  
22 purposed of IVVO deployment. In the approved CPCN I mention above, full

1 deployment of AMI was not scheduled to commence until 2020. Recently, the  
2 Company has identified an alternative deployment plan due to evolving  
3 technologies that we will bring back to the stakeholders of the AGIS CPCN, as  
4 addressed by Ms. Trammell.



1                   **3. AMI Benefits**

2   **Q. WILL AMI PROVIDE QUANTITATIVE BENEFITS TO THE COMPANY, AND**  
3   **THROUGH THE COMPANY, TO ITS CUSTOMERS?**

4   A. Yes. AMI will provide quantifiable capital savings in the areas of distribution  
5   system management, outage management, and avoided meter purchases. AMI  
6   will also provide O&M savings, particularly with respect to meter reading costs,  
7   field and meter service costs, improvements in customer care, and distribution  
8   management and outage management activities. We also expect some savings  
9   with respect to reductions in energy theft, reduced consumption on inactive  
10   premises, and reduced uncollectible and bad debt expense. We anticipate that  
11   these quantitative benefits will begin to be realized starting in 2021 and will  
12   enhance the customer experience by improving the information available to  
13   customers, improving the information available to the Company and how we  
14   interact with customers (i.e. not requiring customers to report outages and being  
15   able to notify customers more precisely when power is restored), improved  
16   reliability for customers, and customer bill savings realized through cost savings.

17               Public Service also anticipates a number of benefits that are not readily  
18   quantifiable. These non-quantifiable benefits were discussed extensively by  
19   Company in the approved CPCN.

1 **Q. DOES THE COMPANY ANTICIPATE THAT AMI WILL PROVIDE THE SAME**  
2 **BENEFITS AS THOSE THAT WERE PRESENTED IN PROCEEDING NO. 16A-**  
3 **0588E?**

4 A. Yes. The Company anticipates that AMI will provide the same benefits as what  
5 the Company presented in Proceeding No. 16A-0588E. However, as part of the  
6 AGIS CPCN Settlement, the Company agreed to modify its meter deployment  
7 schedule, with meter installations not beginning until late 2019, and taking place  
8 over a longer period of time. At this time, meter installations are scheduled to be  
9 completed in 2024. Benefits are expected to be realized when a critical mass of  
10 meter installations have taken place, thus in the latter years of the deployment  
11 schedule. These benefits will assist the Company in managing the distribution  
12 system and provide our customers with an enhanced electric service experience.

13 **Q. PLEASE DESCRIBE THE CAPITAL BENEFITS IN MORE DETAIL.**

14 A. As mentioned above, AMI will provide quantifiable capital savings in the areas of  
15 distribution system management, outage management, and avoided meter  
16 purchases. These types of benefits are described below.

17 • *Distribution System Management.* AMI data can be aggregated at varying  
18 levels of the distribution system that include the tap, transformer, and service  
19 lines among other distribution system equipment. This data will be used to  
20 prioritize distribution grid improvements and more efficiently plan and design  
21 the system. This data can then be used to determine optimum installation  
22 and replacement of distribution assets as well as optimizing inventory levels.

1 The Company estimates that a one percent capital benefit will be achieved in  
2 reducing distribution capital expenditures through more efficient installation  
3 and replacement of distribution assets related to reliability and capacity  
4 projects. This will benefit customers because the Company will avoid capital  
5 expenditures that would otherwise go into rate base, and also assist in  
6 ensuring that distribution grid improvements will be made where and when  
7 they will impact the grid (and our customers) most effectively.

- 8 • *Outage Management Efficiency.* AMI will enable increased outage  
9 management efficiencies by providing automated outage notification and  
10 restoration confirmation (power-on information) to the Company's Outage  
11 Management System ("OMS"). Power loss information is identified by an AMI  
12 meter's last gasp. Outage notification from the AMI meters will provide the  
13 Company with a more timely and accurate scope of an outage without relying  
14 on customers to report an outage. The restoration confirmation that will be  
15 provided by AMI meters also enables the Company to focus and optimize its  
16 restoration efforts on active outages, minimizing field trips where outages do  
17 not exist—also known as "Okay on Arrival" outage calls. The automated  
18 outage information provided by the AMI meters will then assist the Company  
19 in restoring power more quickly because the Company will no longer be  
20 dependent upon customers notifying the Company of a power loss. These  
21 increased outage management efficiencies will enhance the customer  
22 experience by enabling quicker response and restoration to customer outages

1 and will limit requirements on the customers as they will not have to report  
2 outages as they have to today and will enable enhanced communication by  
3 being able to notify them more precisely when power is restored. We  
4 estimate that AMI will contribute a ten percent efficiency gain from storm-  
5 related capital costs.

- 6 • *Avoided Meter Purchases:* The estimated benefits of avoided meter  
7 purchases were derived by comparing costs of a “business as usual”  
8 scenario, which includes business operations with existing installed meters, to  
9 the costs of implementing a new AMI meter population. Under the business  
10 as usual scenario, the Company would continue to replace and retire meters  
11 due to failures, performance, and age at projected costs. The AMI meter  
12 scenario assumes replacing the existing meters with meters that have a lower  
13 retirement rate.

14 **Q. PLEASE DESCRIBE THE O&M EXPENSES-RELATED BENEFITS THAT AMI**  
15 **WILL PROVIDE.**

- 16 A. As noted above, AMI will also provide savings to O&M expenses, particularly with  
17 respect to meter reading costs, field and meter service costs, improvements in  
18 customer care, and distribution management and outage management activities.  
19 The reductions in Company costs will be experienced by customers through their  
20 bills for electric service.

1 **Q. PLEASE DESCRIBE THE REDUCTION IN METER READING EXPENSES IN**  
2 **MORE DETAIL.**

3 A. The benefits related to meter reading expenses will be realized through the  
4 elimination of contracted manual meter reading and the reduction of 31 full-time-  
5 equivalent positions and their associated fleet costs specific to meter reading.  
6 Public Service's goal is to reduce headcount is through natural attrition, which  
7 includes position reassignments and expected retirements.

8 **Q. PLEASE DESCRIBE THE REDUCTION IN FIELD AND METER SERVICES IN**  
9 **MORE DETAIL.**

10 A. AMI meters equipped with internal service switches can be operated remotely,  
11 thereby reducing the need to deploy personnel to manually connect or reconnect  
12 customers, or to take special meter readings at customer premises. Customers  
13 will benefit because the Company will be able to switch meters on or off nearly  
14 instantaneously and Company personnel will be able to perform trouble-shooting  
15 activities remotely. Customers will not have to wait for Company personnel to  
16 arrive on-site in order to resolve issues. And customers will not need to  
17 experience the inconvenience or nuisance of a visit to their premises. We  
18 estimate that these capabilities will benefit the Company through a reduction in  
19 O&M costs generally in proportion to the cumulative number of meters installed  
20 to the Company's total number of customers, in the following areas:

21 • *Reduction in manual disconnection and reconnection of meters:* Manual  
22 disconnects and reconnects of residential meters occur for reasons including

1 credit, customer requests, and revenue assurance. We estimate a reduction  
2 of approximately 90 percent of manual disconnections and reconnections  
3 through remote-controlled capabilities.

- 4 • *Reduction in manual off-cycle and special meter reads:* The Company  
5 estimates an annual reduction in nearly all of these types of manual reads.  
6 This benefit will begin to be realized proportionate to the number of AMI  
7 meters installed.

- 8 • *Reductions in nuisance stopped meter orders:* These are meter exchange  
9 orders that are system-generated because there was no energy consumption  
10 on the meter since the last billing meter reading. These orders may also be  
11 system-generated because the energy consumption reported is lower than  
12 expected as compared to Company-established data validation criteria for  
13 high or low consumption. In either of these two situations, there may be valid  
14 reasons for low or no energy consumption such as the premise being vacant,  
15 the meter being installed on seasonal load such as cabins, sprinklers, or  
16 ballparks, or the customer may be disconnected at the transformer or ahead  
17 of the meter. The diagnostic and analytical tools available through AMI are  
18 estimated to eliminate approximately 60 percent of these types of field trips.

- 19 • *Reduction in customer equipment problem outages:* Remote read access to  
20 meters will enable the Company to determine if an outage exists on the  
21 Company side of the meter, which is expected to significantly reduce costs  
22 associated with field trips that are not associated with company equipment

1 problems. For this analysis, the Company conservatively estimates a 50  
2 percent reduction in such field trips.

3 • *Reduction in “Okay on Arrival” outage field trips:* Public Service estimates a  
4 50 percent reduction in “Okay on Arrival” outage field trips due to better data  
5 through AMI.

6 • *Reduction in field trips for voltage investigations:* The Company estimates a  
7 reduction of approximately 60 percent of these types of field trips due to  
8 voltage investigations that will be able to be completed remotely.

9 **Q. PLEASE DESCRIBE THE ESTIMATED BENEFITS RELATED TO COSTS FOR**  
10 **CUSTOMER CARE.**

11 A. Public Service anticipates a reduction in customer call volumes and a  
12 corresponding reduction in the Company’s back-office costs related to customer  
13 accounts due to the deployment of advanced meters and the implementation of  
14 AMI. The reduction in customer call volumes corresponds to the reduced need  
15 for customers to have to contact the Company to resolve electric service issues  
16 because the advanced meters will provide information to the Company directly,  
17 enabling the Company to proactively address service issues. Public Service  
18 anticipates that these improvements in customer care will provide financial  
19 benefits.

1 **Q. ARE THERE OTHER O&M EXPENSE BENEFITS THAT WILL BE PRODUCED**  
2 **BY AMI?**

3 A. Yes. The outage management efficiency that I discussed above will also  
4 produce O&M expense benefits.

5 **Q. ARE THERE ADDITIONAL QUANTIFIABLE BENEFITS THAT CUSTOMERS**  
6 **AND THE COMPANY WILL REALIZE AS A RESULT OF AMI**  
7 **IMPLEMENTATION?**

8 A. Yes. The timely reporting by the AMI meters of specific conditions in need of  
9 evaluation will allow the Company to correct these conditions more quickly and  
10 more quickly respond to customers. The availability of this information will also  
11 enable Public Service to detect and reduce meter tampering and energy theft,  
12 and to differentiate those instances more quickly from dead and malfunctioning  
13 meters. The Company has estimated a 0.25 percent gain in residential and  
14 small commercial customer (base rate) revenue due to these added capabilities  
15 of AMI meters.

16 Additionally, the Company will be able to remotely disconnect service on  
17 inactive residential and small commercial meters. The Company estimates a 50  
18 percent reduction in consumption on inactive residential meters.

19 Also, the Company estimates an eight percent reduction in residential  
20 customer bad debt. This information is consistent with data provided to the FERC  
21 based on other utilities' pre- and post-AMI deployment.



1           **C. The Field Area Network (FAN)**

2                   **1. FAN Functions and Capabilities**

3   **Q.    WHAT IS THE FAN?**

4   A.    The FAN is a wireless communications network that provides connectivity  
5        between substations and field devices up-to and including the customer meter.  
6        Through the substation's connectivity to the Company's existing Wide Area  
7        Network ("WAN"), the FAN enables back-office applications<sup>7</sup> to directly  
8        communicate with field devices providing near real-time usage information for  
9        both customers and the Company. The WAN is an intermediate link in the  
10       Company's communication system that provides high-speed, two-way  
11       communications capabilities and connectivity in a secure and reliable manner  
12       between Public Service's core data centers and its service centers, generating  
13       stations, and substations. The FAN's connections to the WAN will be primarily at  
14       substations on the distribution system.

15   **Q.    WHY IS PUBLIC SERVICE IMPLEMENTING FAN TECHNOLOGY?**

16   A.    Public Service's FAN will be a resilient communications network that enables  
17        two-way communication of information and data between the Company's existing  
18        infrastructure located at its substations and new or planned field devices,  
19        including reclosers, feeders, electric meters, capacitor banks, and virtually any  
20        other endpoint field device capable of communications, as those devices are  
21        installed or upgraded with communications modules. The FAN will securely and

---

<sup>7</sup> "Back office" applications and systems are those that actually use and manipulate the data and perform specific business functions, including energy management system applications.

1 reliably address the need for increased communication capacity that arises from  
2 grid advancements.

3 **Q. WHAT ARE THE PRINCIPAL COMPONENTS OF THE FAN?**

4 A. The FAN will consist of two separate wireless technologies: (a) a lower-speed  
5 Wireless Smart Utility Network (“WiSUN”) mesh network; and (b) a high-speed  
6 point-to-multipoint (“PTMP”) Worldwide Interoperability for Microwave Access  
7 (“WiMAX”) network. Attachment c-5 provides an illustration of the principal  
8 components of the FAN. The WiSUN and WiMAX technologies are discussed in  
9 more detail by Company witness Mr. Harkness.

10 The WiSUN mesh network will communicate directly with the AMI  
11 infrastructure (such as the advanced meters) and the Distribution Automation  
12 (“DA”) field devices used for the IVVO advanced application. The flow of  
13 communications between field devices, meters, and WiSUN access points  
14 through a mesh-styled network is illustrated in Attachment CSN-5. The term  
15 “mesh” refers to the network’s topology, which resembles the interlaced design of  
16 mesh material.

17 The WiMAX network will provide redundant, reliable, and secure  
18 connectivity between the WiSUN mesh network and the Company’s WAN. The  
19 DA field devices and WiSUN access points connect to the WiMAX base stations  
20 (located largely at the Company’s substations) via wireless communication  
21 modules that are integral to those devices.

1 Through the substation's connectivity to the WAN, the FAN (including the  
2 WiMAX network and the downstream WiSUN mesh network) will enable the  
3 Company's advanced applications (such ADMS and AMI, and sub-applications,  
4 including IVVO, FLISR, and FLP) to communicate with the field devices that  
5 implement those applications and sub-applications.

6 **Q. PLEASE DESCRIBE THE INFRASTRUCTURE AND DEVICES THAT WILL BE**  
7 **INSTALLED AS PART OF THE WISUN MESH NETWORK TO SUPPORT AMI**  
8 **AND IVVO.**

9 A. The core mesh infrastructure will consist of three main device types:

- 10 • *Access Points*: device that will link the Company's endpoint devices that are  
11 enabled with wireless communication modules with the rest of the Company's  
12 communications network; located primarily on distribution poles and other  
13 similar structures.
- 14 • *Repeaters*: range extenders and are used to fill in coverage gaps where  
15 devices would be otherwise unable to communicate; located primarily on  
16 distribution poles and other similar structures.
- 17 • *Endpoint Devices*: include AMI meters and DA field devices, such as the  
18 intelligent FLISR and IVVO field devices, that have built-in mesh radios. The  
19 former will be located on customer premises; the latter will be co-located with  
20 either pole-mounted or pad-mounted distribution devices.

1 **Q. PLEASE DESCRIBE THE INFRASTRUCTURE AND DEVICES THAT WILL BE**  
2 **INSTALLED AS PART OF THE WIMAX NETWORK.**

3 A. The WiMAX network will consist of two main components: (1) base stations, and  
4 (2) customer premise equipment (“CPE”)<sup>8</sup>.

5 Base stations will serve as the key communication points between the  
6 substation WAN and the WiSUN (mesh) network. Base stations will  
7 communicate with CPEs in the field and, through the substations’ connection to  
8 the WAN, enable end-to-end communication between the intelligent field devices  
9 and the Company’s advanced applications and other back office applications.

10 At substations, there will be a base station with up to three radios that will  
11 communicate multi-directionally with CPEs out in the field of operations. Where  
12 possible, the base stations at the substations will be mounted on existing poles  
13 or structures in order to ensure an appropriate height. In some cases, new poles  
14 may need to be deployed if a structural analysis of the designated existing poles  
15 indicates that added weight would cause a stability issue. CPEs will be mounted  
16 on distribution poles in the field of operation.

17 **Q. HOW WILL THE FAN TECHNOLOGIES BE CONNECTED TO AND**  
18 **INTERFACE WITH EACH OTHER AND THE COMPANY’S EXISTING WAN?**

19 A. The WiMAX network and WiSUN mesh network will communicate wirelessly as  
20 the WiSUN mesh access points communicate with the CPEs that make up the

---

<sup>8</sup> CPE is a common term in the network industry that refers to specific equipment. In the term “CPE”, the “customer” refers to Public Service (or a similarly-situated entity using this equipment), which is a customer of the equipment manufacturer. It does not refer to any specific customers of Public Service, or to Public Service’s customers generally.

1 WiMAX network, and the CPEs in turn communicate back to the base stations at  
2 the substation.

3 The WiMAX base stations will be connected to the pre-existing WAN  
4 connections at the substation, which, in turn, will enable connectivity back to the  
5 data center locations.

6 **Q. HOW WILL THE FAN SUPPORT OR INTERACT WITH ADMS?**

7 A. The FAN infrastructure will ultimately provide data from endpoint devices, such  
8 as meters and field devices to the WAN, which will then deliver data to ADMS,  
9 and also enables commands to be transmitted to the field devices from ADMS.

10 **Q. HOW DOES THE FAN SUPPORT OR INTERACT WITH AMI AND IVVO?**

11 A. An AMI system is an integrated communication system that involves the FAN  
12 and the advanced meters. The WiSUN integrates with the advanced meters  
13 because each meter includes a communication module, and these  
14 communications modules form the majority of the mesh network. The mesh  
15 network allows the advanced meter to communicate its measurement data,  
16 power status, voltage current, usage history, and demand information back to the  
17 Company.

18 Additionally, the FAN integrates with IVVO because voltage information  
19 collected by the advanced meters is communicated to the Company via the FAN.  
20 Receiving this information allows the Company to increase or decrease voltage  
21 to the optimum level on a system-wide basis while ensuring all customers are  
22 within the acceptable voltage range allowable under the Company's tariffs.

1 **Q. HOW WILL THE FAN SUPPORT OR INTERACT WITH FLISR (AND FLP)?**

2 A. The FLISR/FLP distribution equipment (*i.e.*, feeder-level devices) will have  
3 embedded communication modules that will communicate with access points in  
4 the mesh network or directly to WiMAX base stations. The FAN will enable two-  
5 way communication between these advanced field devices and ADMS.


6 **2. FAN Implementation and Costs**

7 **Q. WHAT WORK IS DISTRIBUTION UNDERTAKING TO IMPLEMENT THE FAN?**

8 A. The Company engaged in comprehensive planning for implementation of the  
9 FAN beginning in 2016. This task is a joint effort between Business Systems and  
10 Distribution, with Business Systems primary responsible for the installation of  
11 WiMAX base stations and Distribution resources responsible for the installation  
12 of devices that will be located on Distribution poles (CPE's, AP's and repeaters  
13 primarily). For the Distribution Business Area, preparations for the FAN consist  
14 largely of make ready work for the devices to be placed on the distribution  
15 system, and the procurement and installation of hardware—that is, pole-mounted  
16 devices. An example of make-ready work includes situations where a pole  
17 needs to be modified or replaced in order to support a particular piece of  
18 communications hardware; in these situations, Distribution is responsible for  
19 modifying or replacing the pole. The Company began make-ready work in 2017  
20 and equipment installations in 2018. The FAN infrastructure must be in place in  
21 order for the intelligent field devices needed for IVVO to communicate with  
22 ADMS, and for the AMI meters to communicate to the AMI head-end and ADMS.

1 Figure CSN-D-3 shows a timeline of activities for implementation of the FAN.

2 **Figure CSN-D-3**



3 **Q. WHAT ARE THE PRIMARY COMPONENTS OF DISTRIBUTION'S CAPITAL**  
 4 **FORECAST FOR THE FAN?**

5 A. The primary components of the Distribution Business Area's capital forecast,  
 6 shown in Table CSN-D-7 and Attachments CSN-1 and CSN-2, for the FAN are  
 7 (1) make ready work (labor and hardware), and (2) FAN device hardware and  
 8 installation (labor and hardware).

9 **Q. HOW WAS THE CAPITAL FORECAST FOR THE FAN DERIVED?**

10 A. Although Distribution is supporting the FAN deployment through the installation  
 11 of certain devices, Business Systems was primarily responsible for developing  
 12 the forecast for the components of the FAN. Accordingly, Company witness Mr.  
 13 Harkness discusses the development of the FAN forecast.

1 **Q. WILL THE FAN PROVIDE BENEFITS TO THE COMPANY AND ITS**  
2 **CUSTOMERS?**

3 A. Yes. The FAN is an essential component of our AGIS initiative, so customers will  
4 benefit from the FAN's support of, and interaction with, other programs and  
5 technologies.

6 **D. Integrated Volt-VAr Optimization (IVVO)**

7 **1. IVVO Functions and Capabilities**

8 **Q. WHAT IS IVVO?**

9 A. As mentioned above, IVVO stands for Integrated Volt-VAr Optimization. IVVO is  
10 an advanced application that automates and optimizes the operation of the  
11 distribution voltage regulating devices and VAr control devices. Enhanced  
12 voltage control will help achieve the following benefits to the operation of the  
13 distribution system and our customers:

- 14 • Reduction of distribution electrical losses;
- 15 • Reduction of electrical demand;
- 16 • Reduction of energy consumption; and
- 17 • Increased ability to host DER.

18 Fundamentally, IVVO can be characterized as a demand-side management  
19 (“DSM”) tool that allows the utility to control voltage without requiring behavioral  
20 changes from customers.



1 **Q. WHY IS PUBLIC SERVICE IMPLEMENTING IVVO TECHNOLOGY?**

2 A. The current distribution system has the capability to monitor voltages at the  
3 substation but does not have the capability to allow the Company to constantly  
4 monitor voltage levels throughout its feeders. As a result, the Company must  
5 often operate the system at a higher voltage than what would otherwise be  
6 required to ensure the appropriate voltage at the end of a long feeder.

7 The Company's proposed IVVO application will allow voltage to be  
8 monitored along the entire length of the feeder and at selected end points (rather  
9 than only at the substation). This insight into the voltage levels will allow the  
10 Company to utilize lower voltages across the entire feeder at most times.

11 Maintaining proper voltage levels throughout the electric distribution  
12 system is one of the most important challenges utilities face. Utilities seek to  
13 provide electric service to customers within a specific voltage range because  
14 customer equipment, appliances, and devices may not operate satisfactorily  
15 when electricity is supplied at voltages outside of the appropriate range.  
16 Customer demand for electricity changes throughout the day, which means the  
17 power flowing through distribution systems and voltage levels on feeders  
18 increase and decrease throughout the day to meet changing loads.

19 **Q. HOW WILL THE TECHNOLOGY OPTIMIZE VOLTAGE?**

20 A. Voltage optimization is accomplished by "flattening" a feeder line's voltage  
21 profile—or, in other words, narrowing the bandwidth of the voltage from the head-  
22 end of the feeder (at the substation) to the tail-end in concert with capacitors and

1 other voltage-regulating devices (discussed below) for voltage support. In the  
2 Company's IVVO model, voltage will be monitored along the feeder and at select  
3 end points (rather than only at the substation), allowing the head-end voltage to  
4 be significantly lower at most times.

5 Voltage optimization (i.e., managing the overall voltage profile of the  
6 feeder) will reduce demand and energy consumption while still ensuring that  
7 voltage levels are adequate for providing safe and reliable power to customers at  
8 all points along the distribution feeders, including the end of the feeders. IVVO  
9 will also reduce the electrical losses on the distribution system.

10 **Q. WHAT WILL BE THE PHYSICAL COMPONENTS OF IVVO?**

11 A. There will be four principal utility equipment components of IVVO:

- 12 • Capacitors;
- 13 • Secondary static VAr compensators ("SVCs");
- 14 • Voltage sensing devices; and
- 15 • Load Tap Changers ("LTC").

16 **Q. PLEASE DESCRIBE THE CAPACITORS.**

17 A. Electric loads, like motors, require two types of power to operate: active and  
18 reactive power. Distribution line capacitors are located at various points on a  
19 distribution feeder and provide local static VAr support or reactive power. By  
20 doing so, they help to limit both voltage drop and line losses across the  
21 distribution system. Capacitors are currently switched on and off based only on  
22 local conditions. The Company will continue to use its existing capacitor banks

1 and will install new capacitors as part of this project. There will typically be three  
2 to six capacitors installed per feeder.

3 **Q. PLEASE DESCRIBE THE SVCS.**

4 A. The SVCs are electronic secondary capacitors that will provide fast, variable  
5 voltage support to help stabilize and regulate the voltage. Aside from an earlier  
6 pilot program involving SVC devices that was implemented on feeders  
7 interconnected to two substations, these devices will be a new technology  
8 introduced to Public Service's distribution system. Each SVC device will be able  
9 to act in less than a cycle (a cycle is defined as 1/60 of a second since the United  
10 States AC frequency is 60 Hz), as opposed to a traditional utility capacitor device  
11 that operates on a 60-90 second time delay. These devices will provide dynamic  
12 voltage response for load, and will be located closer to customers or nearer the  
13 edge of the grid than the Company's existing capacitors. The devices'  
14 capabilities will enhance the system's ability to respond to the variability of  
15 renewable DERs such as solar facilities and intermittent distributed resources.  
16 The Company will strategically place approximately 4,350 SVC devices along  
17 feeders that need additional voltage support.

18 **Q. PLEASE DESCRIBE THE VOLTAGE SENSING DEVICES.**

19 A. IVVO requires end-of-line voltage sensing to monitor the voltage and ensure it is  
20 compliant with American National Standards Institute ("ANSI") Standard C84.1.  
21 The Company intends to use AMI meters as sensors to provide near real-time  
22 voltage sensing.

1 **Q. PLEASE DESCRIBE THE LTCS.**

2 A. Substation transformers equipped with LTCs will enable voltage regulation by  
3 varying the transformer ratio or tap. LTCs typically have 16 taps above and  
4 below neutral (33 taps total) and each tap adjusts the transformer turns ratio by  
5 0.375 percent. LTCs are currently monitored and locally controlled based on the  
6 local bus voltage. LTCs raise or lower the voltage by tapping up or down based  
7 on the settings of the local controller and the demand of the substation  
8 transformer.

9 **Q. HOW WILL IVVO INTERACT WITH THE OTHER COMPONENTS OF THE**  
10 **AGIS INITIATIVE?**

11 A. As mentioned above, advanced meters will act as the voltage sensing device and  
12 collect voltage information at each service point, which will be transmitted back to  
13 the ADMS through the FAN. ADMS will take the inputs from these devices and  
14 compute the most efficient way for the system to operate and respond to  
15 changes. IVVO, through ADMS, will implement automated activities such as  
16 opening and closing of capacitors, and sending new settings to LTCs and SVCs.  
17 The LTC control devices will take direction from ADMS, which will make  
18 decisions based on knowledge about the entire system, rather than only about  
19 voltage at a single point. As a centralized system, ADMS will be able to control  
20 the distribution devices to work in unison and dynamically react to customer  
21 energy usage that is being increasingly complex.

1                   **2. IVVO Implementation and Costs**


2   **Q.   WHAT WORK IS DISTRIBUTION UNDERTAKING TO IMPLEMENT IVVO?**

3   A.   Implementation of IVVO is on a five-year deployment schedule that began in  
4       2017. In that year, Distribution engaged in initial planning for the IVVO advanced  
5       application and performed an initial deployment of medium voltage capacitor  
6       banks and substation load tap changer control upgrades. These devices were  
7       placed in-service upon installation. The deployment priority of the intelligent field  
8       devices has been determined based on considerations of demand and energy on  
9       the feeder, whether feeder lines and associated facilities are underground or  
10      overhead, and the location of existing capacitors. Deployment of devices on  
11      feeders is grouped by substation to gain efficiency benefits in localized areas.  
12      Distribution is responsible for the acquisition and installation of the physical  
13      devices that will enable the IVVO advanced application.

14           In the second quarter of 2018, the Company completed its RFP process  
15      for a SVC vendor, where it evaluated three different vendors based on a variety  
16      of factors including cost per unit, number of devices deployed across different  
17      utilities, support capabilities, and technical capabilities, ultimately selecting  
18      Varentec's Edge of Network Grid Optimization ("ENGO") unit as the best  
19      amongst these factors. Contract negotiations were completed in the third quarter  
20      of 2018, and we received our first shipment of SVC units late in the same  
21      quarter.

1           Distribution will also be responsible for the system analysis to determine  
 2 the appropriate placement of the devices described above. There will also be  
 3 make-ready work to complete before installing these devices, such as  
 4 reconfiguring the location of a pole to allow an advanced application device to be  
 5 placed on that pole or reconfiguring an underground cable so that a pad-mounted  
 6 piece of equipment can interconnect with it. Figure CSN-D-4 shows a timeline of  
 7 IVVO implementation activities, including device deployments.

**Figure CSN-D-4**



9 **Q. WAS THE DISTRIBUTION BUSINESS AREA PRIMARILY RESPONSIBLE**  
 10 **FOR DEVELOPING THE FORECAST FOR IVVO?**

11 A. Yes. Therefore, I describe the forecast development process for IVVO in more  
 12 detail. After the Company identified IVVO as an advanced application to be  
 13 included in its AGIS initiative, the Distribution Business Area developed its IVVO  
 14 forecast by using data from actual installations of comparable devices, as well as  
 15 pricing details from vendor pricing and pilot projects. Some aspects of IVVO

1 implementation, including a software application and ADMS integration, are  
2 discussed and supported by Company witness Mr. Harkness.

3 **Q. WHAT ARE THE PRIMARY COMPONENTS OF THE IVVO CAPITAL**  
4 **FORECAST FOR ADVANCED APPLICATIONS?**

5 A. The primary components of the IVVO capital forecast, shown in Table CSN-D-7  
6 and Attachments CSN-1 and CSN-2, include: (1) device costs, and (2)  
7 installation costs, which include project management, labor, and device  
8 operations.

9 **Q. HOW DID THE DISTRIBUTION BUSINESS AREA DERIVE THE CAPITAL**  
10 **FORECAST FOR THE IVVO DEVICE COSTS?**

11 A. The Company was able to use actual costs to develop the capital forecast for the  
12 IVVO devices. Previous construction projects across Xcel Energy provided the  
13 basis for primary capacitor bank costs. The substation engineering group  
14 compiled estimate summaries for several different sites, and those were  
15 averaged to provide estimated substation costs. Finally, the Company had a  
16 pilot program testing SVC devices from Varentec, Inc. that began in 2013.  
17 Quotes provided from Varentec and actual costs during that pilot were used to  
18 estimate costs for that component.

19 **Q. HOW DID THE DISTRIBUTION BUSINESS AREA DERIVE THE CAPITAL**  
20 **FORECAST FOR IVVO INSTALLATION COSTS?**

21 A. Many of the devices involved in the IVVO deployment are not new to the  
22 Company. As such, the Company was able to use actual costs to develop the

1 forecasts to implement the IVVO solution. With respect to the new SVC devices,  
2 Public Service has already engaged in a limited pilot installation of these devices  
3 on select distribution feeders, as discussed above; therefore, the Company was  
4 able to use actual costs for these devices as well. The Company is using  
5 primarily contract labor for the installation of IVVO devices. The forecast for  
6 labor costs for device installation were developed using contractor wage scales.

7 **Q. DOES IVVO PROVIDE BENEFITS TO THE COMPANY AND ITS**  
8 **CUSTOMERS?**

9 A. Yes. As described above, through the implementation of IVVO, the Company will  
10 be able to control the voltage on distribution feeders to a much tighter tolerance,  
11 permitting the Company to lower the voltage on that controlled feeder while still  
12 maintaining a high level of service quality. This lower voltage will result in a  
13 customer's devices operating more efficiently, and will effectuate energy and  
14 demand savings for customers and the system. The ability to avoid capacity,  
15 energy (fuel) costs, and defer capital investments will provide quantifiable  
16 benefits to our customers and the Company. Deployment of IVVO devices  
17 began in 2017; however we will not reach a critical mass of devices to realize  
18 these avoided energy and capacity benefits until 2019. IVVO will also provide  
19 benefits to customers that are not easily quantifiable. For example, the  
20 customers whose feeders are equipped with IVVO assets will experience higher  
21 efficiencies from their personal electrical devices and equipment because of the  
22 voltage management, which will enable their devices and equipment to consume



1 less energy without having to take an action or change any use or behavior, or  
2 make any investment. This improved efficiency will result in lower bills for those  
3 customers. In addition, lower-income customers will have access to energy  
4 efficiency savings without having to participate in a specific low-income or  
5 efficiency-related program. Furthermore, there will be environmental benefits  
6 resulting from increased energy efficiency. The improved energy efficiency can  
7 result in reduced demand for electric generation, and thus a reduction in carbon  
8 emissions caused by certain types of generation resources. The reduction in  
9 greenhouse gas emissions, in turn, will provide environmental and societal  
10 benefits. The enhanced voltage management capabilities will also enable our  
11 system to have increased capacity to host DERs.

12 **Q. WHY ARE THE IVVO COSTS REASONABLE FOR CUSTOMERS TO**  
13 **SUPPORT?**

14 A. The service area for IVVO encompasses the majority of the Company's system  
15 load and its customers, while also including system infrastructure that inherently  
16 reacts positively to IVVO. For example, the IVVO service area generally includes  
17 feeders that are shorter and have stronger interconnections to surrounding  
18 feeders and substations.

19 The deployment of IVVO was also crafted to minimize cost impacts.  
20 Substation LTC control upgrades are being designed such that their replacement  
21 impacts as few other substation components as possible. The majority of  
22 Distribution device costs are associated with medium voltage capacitor banks,

1 which have a low cost per Kilovolt-Amperes Reactive (“kVAr”). Existing capacitor  
2 banks also will be utilized as much as possible where they meet the technical  
3 requirements of IVVO. The addition of the lower voltage SVCs provides an  
4 appreciable benefit increase as well, and previous pilot projects in the Company's  
5 service territory have shown very favorable results from these devices.

6 **Q. IS THERE ANYTHING ELSE REGARDING IVVO YOU WOULD LIKE TO**  
7 **ADDRESS?**

8 A. Yes. There is one aspect of the AGIS CPCN Settlement related to IVVO I would  
9 like to address. Specifically, page 11 of the Commission-approved AGIS CPCN  
10 Settlement, Section II(D)(1)(b) provides:

11 In the event the Company completes a base rate case that includes  
12 any portion of the IWO usage reductions in the forecasted or actual  
13 billing determinants, the Company shall present those anticipated  
14 reductions in a transparent manner, and propose an adjustment to  
15 the annual IWO recovery calculation to account for changes to  
16 billing determinants in order to prevent and avoid double recovery.  
17 After all IWO usage reductions associated with the initial  
18 deployment are captured in a base rate case, the Company will  
19 discontinue the IWO recovery treatment provided for in this  
20 Settlement Agreement.

21 **Q. DOES THIS PROVISION NEED TO BE ADDRESSED IN THIS PROCEEDING?**

22 A. No. Because the Company did not experience any usage reductions attributable  
23 to IVVO during the 2018 HTY, the Company is not proposing an adjustment to  
24 the IVVO recovery reduction in this proceeding.

1 **Q. WILL THIS PROVISION BE USED IN THE FUTURE?**

2 A. Yes. The Company is expecting to achieve IVVO energy savings in 2019 and  
3 beyond. Estimates of IVVO energy savings will be calculated in the year after  
4 they occur.

5 **E. Fault Location Isolation and Service Restoration (FLISR) and Fault**  
6 **Location Prediction (FLP)**

7 **1. FLISR and FLP Functions and Capabilities**

8 **Q. WHAT ARE FLISR AND FLP?**

9 A. As mentioned above, FLISR stands for Fault Location Isolation and Service  
10 Restoration. FLISR involves deploying automated switching devices with the  
11 objective of decreasing the duration and number of customers affected by any  
12 individual outage. FLISR can noticeably reduce the amount of time customers  
13 will experience outages from faults, enable the Company to react to the event  
14 more quickly, and improve utility performance metrics such as system average  
15 interruption duration index ("SAIDI") and the system average interruption  
16 frequency index ("SAIFI").

17 Fault Location Prediction, or FLP, is a subset advanced application of  
18 FLISR that leverages sensor data from field devices to locate a faulted section of  
19 a feeder line and reduce patrol times needed to physically locate the fault.

20 **Q. PLEASE DESCRIBE IN MORE DETAIL A FAULT AND FAULT CURRENT.**

21 A. Faults are either temporary or permanent. A permanent fault is one where  
22 permanent damage is done to the system and a sustained outage (i.e., greater  
23 than five minutes) is experienced by the customer. Permanent faults may be the

1 result of insulator failures, broken wires, equipment failure (e.g., cable failure,  
2 transformer failure), or public damage (e.g., an automobile accident impacting a  
3 utility pole). Temporary faults are those where customers experience a  
4 momentary interruption (i.e., less than five minutes). Causes of temporary faults  
5 include lightning, conductors slapping in the wind, or tree branches that fall  
6 across conductors and then fall or burn off.

7 When there is a fault—either temporary or permanent—the current or fault  
8 current is several to many times larger in magnitude than the current that  
9 normally flows due to load. The general profile for fault current is based on the  
10 distance from the substation (fault current is generally highest at the substation,  
11 decreasing as the location is further from the substation), type of fault (e.g., line-  
12 ground fault, three-phase fault), system voltage, and conductor type and size.

13 **Q. DOES FLISR OPERATE FOR ALL OUTAGE EVENTS?**

14 A. No, FLISR devices will operate for outages that occur on the distribution  
15 mainline. Outages that occur on laterals will benefit from FLP information and  
16 outages that occur on the secondary system will benefit from information that will  
17 be made available from the deployment of AMI meters. Although mainline  
18 outages only account for 3 percent of distribution outage events, today they  
19 account for over 30 percent of the distribution SAIDI.

1 **Q. ARE THERE CURRENTLY DEVICES ON PUBLIC SERVICE’S DISTRIBUTION**  
2 **SYSTEM TO ASSIST IN FAULT ISOLATION AND SERVICE RESTORATION?**

3 A. Yes. Public Service currently has small automation programs existing across its  
4 distribution system. In general, reclosers and sectionalizers are used to limit  
5 potential impacts of faults. Reclosers act as circuit breakers and are able to  
6 interrupt a fault event, meaning the recloser opens and the customers  
7 downstream of the recloser experience an outage. This is comparable to a  
8 household ground fault circuit interrupter (“GFCI”) that opens when it detects a  
9 fault or issue, only affecting the devices downstream of the fault or issue, and not  
10 opening the breaker in a household breaker panel. Reclosers can also try to  
11 close a circuit (that has opened due to the fault) a certain number of times (to  
12 clear a temporary fault) before de-energizing all customers downstream. If  
13 successful, the process ensures that all customers on the impacted distribution  
14 feeder do not experience a sustained outage.

15 In addition, once ADMS is operational breakers and reclosers will  
16 measure current during faults (fault current) and report that data to ADMS. This  
17 will allow identification of line sections where the fault may have occurred so  
18 crews can be dispatched to the location of the failure rather than patrolling miles  
19 of line.

20 **Q. WHAT WILL BE THE COMPONENTS OF FLISR AND FLP?**

21 A. There will be four principal components of FLISR:

- 22
- Reclosers;

- 1 • Automated overhead switches;
- 2 • Automated switch cabinets; and
- 3 • Substation Relaying.

4 There will be two main components to FLP:

- 5 • Power sensors; and
- 6 • Substation Relaying.

7 **Q. WHAT ARE RECLOSERS?**

8 A. Reclosers will be pole-mounted remote supervisory reclosing and switching  
9 devices. The Company currently has reclosers on the distribution system. The  
10 new devices will perform the same functions as existing reclosers described  
11 above. The devices will also be able to interrupt a fault event and will be able to  
12 report fault current to ADMS, which can then use that information to execute FLP  
13 to determine the location of the fault. The reclosers will be able to “re-close” after  
14 a fault event to determine if a fault still exists. If the fault does not exist, the  
15 recloser will reclose and restore service. If the recloser determines that there is a  
16 permanent fault after multiple attempts to reclose, the device will communicate  
17 the fault information to ADMS, which will inform the Company of the need to  
18 dispatch a crew to the fault location. In addition, the reclosers will be controlled  
19 by ADMS when there is a permanent fault to automatically restore service.

20 **Q. WHAT IS AN AUTOMATED OVERHEAD SWITCH?**

21 A. Switches are overhead remote supervisory sectionalizing and switching devices.  
22 When a fault occurs, a feeder breaker senses the fault and opens. Although the

1 overhead switches do not communicate directly with the feeder breaker, local  
2 controllers on switches on both sides of the fault would sense the loss of voltage  
3 and open, isolating the fault. However, unlike a recloser, the overhead switches  
4 will not have the capability of reclosing to determine whether there is a  
5 permanent fault. Instead, overhead switches rely on the feeder breakers for the  
6 reclosing functionality.

7 Although automated overhead switches lack the reclosing functionality,  
8 they utilize a compact form factor that makes them a better choice for space-  
9 constrained locations compared to reclosers.

10 **Q. WHAT ARE AUTOMATED SWITCH CABINETS?**

11 A. Automated switch cabinets are pad-mounted sectionalizing and switching  
12 devices. They are motor-operated, remote-controlled devices that are expected  
13 to be utilized for underground feeder installations. They will perform functions  
14 similar to the automated overhead switches for underground feeders.

15 **Q. HOW WILL FLISR FUNCTIONALITY IMPROVE THE CURRENT SITUATION?**

16 A. Public Service currently has an average of 1,745 customers on each feeder.  
17 Because of the Company's current lack of visibility into the conditions on the  
18 distribution system feeders, when a fault occurs Public Service generally relies  
19 on calls from customers to inform the Company of the problem. Once customers  
20 have reported an outage in a given area, Public Service operators dispatch  
21 crews to patrol the area where they believe the fault occurred, based on the  
22 information gathered from the calls. Crews then proceed to isolate the fault and

1 manually close switches to restore service to customers affected by the fault.  
2 The average time to restore a feeder-level fault is 68.3 minutes. Such a fault  
3 affects all customers on that feeder (1,745 on average).

4 With FLISR, the components (described above) will divide the distribution  
5 feeders approximately into thirds, with intelligent switches in place to tie each  
6 section to another feeder when the section that is experiencing the fault is  
7 isolated. When a fault occurs, the system—in coordination with ADMS and FAN  
8 functionality—will automatically restore service to two-thirds of the customers on  
9 a feeder (or 1,163 customers on average) within minutes of the fault, and the  
10 other one-third of customers on the feeder (or 582 customers on average) may  
11 experience shorter service restoration times than the average of 68.3 minutes  
12 today due to the availability of more precise information regarding the location of  
13 the fault, rather than requiring the Company to patrol the length of the entire  
14 feeder with limited knowledge of the general location of the fault.

15 Existing reclosers and intelligent devices will be integrated into the FLISR  
16 scheme. If an existing device is in the correct location to employ FLISR  
17 functionality, this will obviate the need for a new device. Other existing devices  
18 will enhance FLISR's capabilities by enabling greater granularity in switching  
19 arrangements by having more precise voltage, current, and power information.

20 **Q. CAN YOU DESCRIBE IN MORE DETAIL HOW FLISR OPERATES?**

21 A. Yes, in the event of a fault, the FLISR protective devices will reclose or  
22 sectionalize the feeder as they currently do to isolate the fault. In addition,



1 ADMS will provide for remote monitoring and control of FLISR and FLP devices.  
2 When a fault occurs on a FLISR- or FLP-enabled feeder, any of the intelligent  
3 field devices that are exposed to the fault will send a signal to ADMS notifying the  
4 system of the event. Devices that are capable will also send fault current during  
5 the event. ADMS will use both of sets of data, comparing fault current data  
6 against the impedance model (GIS data) to generate an expected fault location.  
7 If that feeder is FLISR-enabled, ADMS will generate a switching plan to isolate  
8 the faulted section based on system conditions, and will issue commands to field  
9 devices on the feeder and adjacent feeders so that non-faulted sections can be  
10 automatically restored, taking into account not only device and feeder loading,  
11 but surrounding substation loading as well. ADMS will then execute the  
12 proposed switching plan and notify the operator of the need to send a crew to the  
13 isolated section to manually investigate the fault event. This process is expected  
14 to take less than five minutes from the occurrence of an outage to operator  
15 notification. ADMS will also be able to run the FLP algorithm and predict which  
16 segment within a FLISR section the fault exists, which will reduce expected patrol  
17 times by crews.

18 **Q. PLEASE DESCRIBE IN MORE DETAIL HOW FLP OPERATES AND HOW IT**  
19 **WILL IMPROVE DISTRIBUTION GRID PERFORMANCE.**

20 A. Public Service is proposing to install up to two sets of three-phase advanced line  
21 power sensors along each feeder targeted for FLP deployment. One set will be  
22 installed on the feeder side of the substation, and another set could be installed

1 down the line. Existing remote fault indicators and new intelligent device  
2 telemetry will be incorporated into the FLP deployment. If an existing device is in  
3 the correct location to employ FLP functionality, this will obviate the need for a  
4 new device. Other existing devices will enhance FLP's capabilities by providing  
5 additional data to improve FLP algorithm performance.

6 Feeders enabled only with FLP will operate in a slightly different manner  
7 from FLISR-enabled feeders. Should a fault occur, FLP devices upstream of the  
8 fault will capture an event occurring and will communicate relevant  
9 measurements during the fault (fault current) to ADMS. ADMS will compare  
10 these measurements to the impedance model and will generate expected fault  
11 locations. It will then notify the operator of these locations (with a level of  
12 certainty for each location), and the operator will dispatch a crew directly to the  
13 expected faulted section (as opposed to having the patrol the entire feeder line,  
14 as in the current situation) to isolate the faulted section. This process is  
15 expected to reduce the patrol time per fault by providing a specific location of the  
16 faulted section and reducing the area needed to be patrolled. However, where  
17 FLP is implemented on its own, the devices will not have the ability to  
18 automatically restore service to the sections of the feeder that are not  
19 experiencing the fault event.

1 **Q. CAN YOU PROVIDE A COMPARISON TO A COMMON HOUSEHOLD**  
2 **SITUATION?**

3 A. Yes, as a comparison, most strings of Christmas lights will not function at all if  
4 any one of the lights has a problem. Identifying the problematic light that causes  
5 the entire strand not to function requires testing each individual light. However,  
6 on a string of hypothetical “smart” Christmas lights, equipped with a centralized  
7 controller (comparable to ADMS) that communicates with each individual light,  
8 the centralized controller would use the data communicated to it by each of the  
9 lights to predict the location of the problematic light(s) to within a small set of  
10 lights. This is comparable to FLP. Once the lights’ centralized controller isolated  
11 the small set of lights with the problem light, it would engage a switch that would  
12 allow the remaining lights to continue to work properly while the problem light is  
13 replaced. This is comparable to FLISR functionality.

14 **2. FLISR and FLP Implementation and Costs**

15 **Q. WHAT WORK IS THE DISTRIBUTION BUSINESS AREA UNDERTAKING TO**  
16 **IMPLEMENT FLISR AND FLP?**


17 A. The FLISR and FLP devices are on a nine-year deployment schedule that began  
18 in 2016. The deployment priority is based on the historical reliability performance  
19 of the feeders, starting with lower performing feeders. Deployment of devices will  
20 be in clusters of three-to-five feeders to gain the operational and reliability  
21 benefits in localized areas. Distribution will be responsible for managing the  
22 engineering, procurement and installation of the physical devices that will enable

1 the FLISR and FLP advanced applications. This work will be done in  
 2 combination with internal labor and third party contractors.

3 Distribution will also be responsible for the system analysis to determine  
 4 the appropriate placement of the devices described above. There will also be  
 5 make-ready work that is necessary to complete in order to install these devices,  
 6 such as reconfiguring the location of a pole to allow an advanced application  
 7 device to be placed on that pole or reconfiguring an underground cable so that a  
 8 pad-mounted piece of equipment can interconnect with it.

9 Figure CSN-D-5 shows a timeline of FLISR and FLP implementation  
 10 activities, including device deployments.

11 **Figure CSN-D-5**



12 **Q. WAS DISTRIBUTION PRIMARILY RESPONSIBLE FOR DEVELOPING THE**  
 13 **FORECAST FOR FLISR AND FLP?**

14 **A.** Yes. Therefore, I describe the forecast development process for FLISR and FLP  
 15 in more detail. After the Company identified FLISR and FLP as advanced

1 applications to be included in the AGIS initiative, Distribution developed its  
2 forecast for FLISR and FLP by using data from actual installations of comparable  
3 devices, as well as pricing details from vendors and pilot projects. Some aspects  
4 of FLISR and FLP implementation, including the integration of the Sensor  
5 Management System (“SMS”) for Aclara sensors into ADMS and ADMS IT  
6 integration are discussed and supported by Company witness Mr. Harkness.

7 **Q. WHAT ARE THE PRIMARY COMPONENTS OF THE FLISR AND FLP**  
8 **CAPITAL FORECAST FOR ADVANCED APPLICATIONS?**

9 A. The primary components of the FLISR and FLP capital forecast, shown in Table  
10 CSN-D-7 and Attachments CSN-1 and CSN-2, include: (1) device costs, which  
11 include device replacements, and (2) installation costs, which include project  
12 management, labor, and commissioning support.

13 **Q. HOW DID DISTRIBUTION DERIVE THE CAPITAL FORECAST FOR THE**  
14 **FLISR AND FLP DEVICE COSTS?**

15 A. The Company was able to use actual costs to develop the capital forecast for the  
16 FLISR and FLP devices, such as the costs for previous, completed projects  
17 utilizing the same equipment that will be deployed for FLISR. Xcel Energy had  
18 previously piloted FLP sensors from Aclara and actual costs from this work were  
19 used to develop forecasts for FLP.

20 With respect to device replacement costs, the Distribution Business Area  
21 experiences a roughly 0.6 percent equipment failure rate per year. This includes  
22 various factors such as product infancy failure rates and equipment failures due

1 to public or environmental damage. This failure rate was applied to total  
2 equipment quantities to determine the number of devices that would need to be  
3 replaced and accurately reflect those costs in the FLISR and FLP deployments.

4 **Q. WHY ARE THE FLISR AND FLP COSTS REASONABLE FOR CUSTOMERS**  
5 **TO SUPPORT?**

6 A. Customer outages are an inevitable part of operating our system and, as  
7 discussed above, the deployment of FLISR and FLP devices will provide our  
8 customers with reliability benefits and reduce the frequency and duration of those  
9 outages by streamlining restoration efforts. Moreover, we are prioritizing areas  
10 that will result in the greatest benefit for our customers by targeting FLISR  
11 deployments to areas that have experienced a higher rate of outages that impact  
12 a greater number of customers across the Public Service system. For customers  
13 that are not located on FLISR-enabled feeders, FLP will provide the Company  
14 with more granular information about the location of a fault so that the Company  
15 can restore service more quickly, rather than having to rely on calls from  
16 customers and having to patrol miles of distribution lines when an outage is  
17 reported.

18 **F. Program and Change Management Supporting AGIS**

19 **Q. WHAT OTHER COSTS ARE INCLUDED IN THE IMPLEMENTATION OF THE**  
20 **FOUNDATIONAL COMPONENTS OF AGIS?**

21 A. Public Service's Distribution Business Area has primary responsibility for the  
22 Program and Change Management work that needs to be done for each

1 foundational AGIS component to ensure a successful implementation of the  
2 AGIS initiative. The work that Distribution is undertaking for these activities is  
3 nearly identical for each foundational component of AGIS.

4 **Q. WHAT IS PROGRAM MANAGEMENT?**

5 A. Program Management is an organizational effort designed to coordinate project  
6 management tasks across individuals and business units that are necessary to  
7 support a transformational initiative such as AGIS. It also provides essential  
8 corporate resources to ensure that the various individual AGIS projects are  
9 completed successfully. The Program Management team will coordinate the  
10 work required for the individual projects that will build the assets that make up the  
11 overall AGIS initiative. The Program Management team is also responsible for  
12 financial analysis and control, accounting, contract management, resource  
13 management, initiative governance, communications and administrative  
14 assistance for each individual project and the overall AGIS initiative. The  
15 Program Management team will also track results, identify and determine if  
16 remedial action is necessary to keep the AGIS initiative on track, and monitor  
17 interdependencies between individual projects. Given the size of this initiative,  
18 Program Management is needed due to the highly interrelated and  
19 interdependent nature of the many components of the AGIS initiative at the  
20 individual project level.

1 **Q. PLEASE DESCRIBE THE COSTS ASSOCIATED WITH PROGRAM**  
2 **MANAGEMENT FOR THE AGIS INITIATIVE.**

3 A. Program Management will include capital costs and O&M expenses. The capital  
4 costs include engaging consultants and contractors throughout the development,  
5 deployment, and conclusion of the AGIS initiative. The Program Management  
6 costs are based on the need to build a Program Management team that will  
7 consist of both internal employees, as well as the engagement of consultants.  
8 This approach is based on the Company's experience with Program  
9 Management for other large-scale projects, and is consistent with its recent  
10 experience implementing the new general ledger and work and asset  
11 management systems.

12 **Q. WHAT IS CHANGE MANAGEMENT?**

13 A. Change Management is a formal discipline that dates back to the 1980's. It is a  
14 systematic approach to effectively execute and manage fundamental  
15 organization changes, related to people, process, technology and data. The  
16 Company's AGIS Change Management framework consists of three main  
17 elements or phases: preparation for the change, management of the change, and  
18 sustaining the change.

19 **Q. WHY IS CHANGE MANAGEMENT NEEDED FOR THE AGIS INITIATIVE?**

20 A. The implementation of the AGIS initiative will impact and transform the job  
21 functions for many of the Company's employees. In order to manage this  
22 transformation and properly engage employees and external stakeholders to



1 ensure a successful transition, a comprehensive Change Management plan is  
2 necessary, particularly because AGIS will fundamentally change nearly all  
3 aspects of the Company's management of its distribution system and how it  
4 interacts with customers. For example, the Company will communicate with  
5 customers differently when it comes to an outage response or how meters are  
6 activated and read. AMI meter data will also provide information to customers  
7 about how they are using energy, rate structures, and energy options available to  
8 a customer. Through Change Management, the Company utilizes a mix of  
9 employees and consultants to support the Company and its employees through  
10 the three main phases of change identified above.

11 **Q. PLEASE DESCRIBE THE COSTS ASSOCIATED WITH AGIS CHANGE**  
12 **MANAGEMENT.**

13 A. Change Management will have capital costs and O&M expenses. The capital  
14 costs include engaging consultants and contractors throughout the development,  
15 deployment, and conclusion of the implementation of the AGIS initiative. Specific  
16 tasks that will be capitalized are those that relate directly to design and  
17 deployment of assets, such as, but not limited to, the development of key design  
18 decisions, training development, functional alignment, integration reviews,  
19 program architecture documentation, technical change management, managing  
20 quality, and performing independent deliverable reviews. The cost estimates for  
21 Change Management were developed independently for each AGIS program.  
22 For example, the AMI Change Management costs were benchmarked against

1 and consistent with those of Ameren Illinois and First Energy Corporation, which  
2 installed AMI projects of a similar size. The Company's Change Management  
3 costs for IVVO and the FAN are consistent with the Company's own experience  
4 in Change Management during its recent experience implementing an enterprise-  
5 wide initiative involving the Company's new general ledger and work asset  
6 management systems (Productivity Through Technology ("PTT") is discussed by  
7 Company witness Daniel C. Brown).

1 **IX. AGIS O&M**

2 **Q. WHAT IS THE PURPOSE OF THIS SECTION OF YOUR TESTIMONY?**

3 A. In this section of my Direct Testimony I support Distribution's O&M expenses for  
4 which the Company seeks recovery in this rate review with respect to the AGIS  
5 initiative, which include the Distribution Business Area's actual 2018 AGIS-  
6 related O&M expenses as well as an adjustment to account for the known and  
7 measurable O&M that the Company anticipates for its AGIS-related Distribution  
8 O&M in 2019, which the Company proposes to utilize as the primary basis for  
9 establishing Distribution's AGIS-related O&M expenses included in the  
10 Company's cost of service, which is supported by Company witness Ms. Blair.

11 **Q. WHAT TYPES OF EXPENDITURES FOR AGIS ARE CLASSIFIED AS O&M**  
12 **EXPENSE?**

13 A. O&M expenses includes those typically associated with construction and the  
14 operating and maintaining of the system, such as contracted labor, materials,  
15 transportation, permitting, restoration, and other services that are carried out in  
16 the normal course of business. During the construction and deployment of the  
17 AGIS field devices, the Company will incur O&M expense because some aspects  
18 of the work will be on existing facilities that must be rebuilt or otherwise modified.  
19 Once the devices are deployed, expenses will be incurred to operate and  
20 maintain the installed devices in the normal course of business.

1 Q. WHAT ARE DISTRIBUTION'S O&M EXPENSES RELATED TO AGIS  
2 IMPLEMENTATION THAT THE COMPANY HAS UTILIZED IN ITS COST OF  
3 SERVICE IN THIS RATE REVIEW?

4 A. Distribution's AGIS O&M expenses are shown below in Table CSN-D-8.

5 **Table CSN-D-8**  
6 **Public Service Electric**

<b>AGIS Distribution O&amp;M</b> (Dollars in Millions)		
<b>AGIS Program</b>	<b>2018</b>	<b>2019</b>
ADMS	0.8	1.1
AMI	0.5	1.7
FAN	0.2	2.0
FLISR	0.3	0.4
IVVO	0.4	1.7
<b>Total*</b>	<b>2.3</b>	<b>6.8</b>

\*There may be differences between the sum of the individual AGIS program amounts and Total amounts due to rounding.

7 Q. WHAT ARE THE PRIMARY COMPONENTS OF DISTRIBUTION'S O&M  
8 EXPENSES?

9 A. The primary components of Distribution's O&M expenses relate to contract labor  
10 costs and training activities. Although AGIS programs will have other types of  
11 O&M expenses, because the implementation and deployment of these programs  
12 and their respective devices are in early stages, costs related to device  
13 replacement or maintenance—such as for the FAN, IVVO, and FLISR—are  
14 expected to be minimal.

1 **Q. PLEASE EXPLAIN THESE EXPENSES AND THE FORECASTED INCREASE**  
2 **IN DISTRIBUTION'S O&M EXPENSES FROM 2018 TO 2019.**

3 A. The forecasted increase in O&M expenses is due to the anticipated increase in  
4 contract labor costs as the AGIS programs are implemented, particularly starting  
5 in 2019. This known and measurable increase in labor costs is the reason the  
6 Company is seeking to adjust its 2018 actual O&M expenses.

7 For example, with ADMS anticipated to go live in 2019, the Company will  
8 need additional resource support for managing the data and testing process,  
9 begin supporting the management of ADMS upon go live, and training individuals  
10 that will be impacted by the ADMS deployment, both continuing through the end  
11 of the ADMS project.

12 For AMI, the primary components of the AMI O&M expenses relate to AMI  
13 operations, and the removal, retirement, and disposal of the AMR meters by the  
14 meter installation vendor. The forecast for AMI Operations is based on costs  
15 associated with external project personnel using known and estimated contractor  
16 costs for the specified personnel. Similarly, the Company plans to have meter  
17 removal, retirement, and disposal of the AMR meters performed by the meter  
18 installation vendor, and the Company is in contract negotiations with the meter  
19 installation vendor to perform these activities.

20 The types of O&M expenses that Distribution will incur for IVVO and  
21 FLISR implementation in 2018 and 2019 are similar to each other and will initially  
22 involve O&M activities that are required such as modifying existing equipment

1 that is in support of the installation of a new device, and device support, which  
2 consists largely of contract labor costs. As more devices are installed, more  
3 resources will be needed to provide support. In future years, programs like the  
4 FAN, IVVO, and FLISR will have greater amounts of costs related to device  
5 replacement, on-going communications network costs, and training activities.

6 Finally, all programs will have O&M expenses related to change  
7 management activities, which involves contractor labor, as discussed above.

8 For these reasons, the Company is making an adjustment to account for  
9 known and measurable AGIS O&M expenses that the Company anticipates for  
10 2019 in the Company's 2018 HTY cost of service, as further explained by Ms.  
11 Blair.

1 **X. RELIABILITY**

2 **Q. WHAT IS THE PURPOSE OF THIS SECTION OF YOUR TESTIMONY?**

3 A. In this section of my Direct Testimony I discuss the Company's historical  
4 reliability and service quality performance and how that performance has  
5 generally improved in recent years, and compare our performance to peers in the  
6 electric utility industry based on industry standard benchmark results. Further, I  
7 discuss the Company's expectations regarding future trends in electric utility  
8 reliability performance and how the AGIS programs will help continue to maintain  
9 the Company's reliability performance at levels that provide strong results for  
10 customers as compared to industry averages. These reliability goals reflect just  
11 one value stream of the AGIS initiative.

12 **Q. PLEASE PROVIDE A HIGH-LEVEL OVERVIEW ON HOW PUBLIC SERVICE  
13 PROVIDES RELIABLE ELECTRIC SERVICE?**

14 A. Public Service provides reliable service by designing the system to limit the  
15 number of outages and the number of customers impacted by an outage. When  
16 there is an outage or when a major storm hits, we respond swiftly and effectively  
17 to restore power. Public Service continues to be a leader in terms of reliability  
18 performance. The Company is consistently in the top performance quartile and,  
19 on average, customers have electric service more than 99.9 percent of the time.

1 **Q. HOW DOES THE COMPANY ENSURE THAT IT IS PROVIDING RELIABLE**  
2 **SERVICE TO ITS CUSTOMERS?**

3 A. Distribution commits capital and O&M investments to maintain reliable electric  
4 service. These generally either mitigate future outages, or improve our ability to  
5 limit any outages to the smallest number of customers for the shortest possible  
6 duration. The Company tracks reliability metrics and measures performance  
7 through benchmarking with other utilities. The Company also has a Quality of  
8 Service Plan (“QSP”) in place with the Commission.

9 **Q. WHAT ARE THE QSP’S RELIABILITY MEASUREMENTS?**

10 A. The QSP has two types of measurements: system level and customer level. For  
11 the system level measurement, the QSP utilizes SAIDI for a selected set of data.  
12 SAIDI is the average duration of interruptions customers experience during a  
13 year quantified in minutes. It is normalized data that focuses on performance of  
14 distribution lines only, and specifically excludes impacts due to public damage,  
15 properly planned outages, and outages deliberately caused in the interest of  
16 public safety. Annual performance targets are defined based on historical  
17 performance within each region separately. Public Service pays its customers  
18 performance penalties if the Company does not meet its target for any region for  
19 two years or more in a row. For the customer based measurements the QSP  
20 has monitoring and penalty structures so that customers receive compensation if  
21 they experience multiple outage events within a given time frame, or if they  
22 experience outage events that last longer than 24 hours. Company witness Ms.



1 Applegate supports the Company's request for a three-year extension of the  
2 QSP.

3 **Q. PLEASE DESCRIBE THE COMPANY'S QSP PERFORMANCE IN 2018.**

4 A. The Company has performed well in 2018 relative to the QSP. For each the nine  
5 QSP reporting regions, SAIDI penalties are paid if the region's Reliability  
6 Warning Threshold ("RWT") is exceeded two years in a row. In 2018, only one of  
7 the nine regions, San Luis Valley, exceeded the Reliability Warning Threshold  
8 ("RWT") and this was mainly attributable to uncontrollable weather events on  
9 February 19, May 20, and May 21. These three days resulted in approximately  
10 27 percent of the SAIDI impact in 2018 for this region. San Luis Valley also  
11 exceeded the target in 2017 resulting in a penalty of \$121,081. The Company  
12 outlines the details of these events in the Annual QSP report for 2018 filed with  
13 the Commission on April 1, 2019 along with Company's plans to continue to  
14 enhance the reliability for this region.

15 For the customer based metric for customers experiencing multiple  
16 interruptions, penalties were paid in 2018 to some of Public Service's  
17 approximately 1.4 million customers. The maximum penalty for Public Service is  
18 \$1 million/year for this metric, with a \$50 maximum paid to any customer. In  
19 2018, Public Service paid \$266,450 as \$50 bill credits to 5,329 customers who  
20 exceeded the Electric Continuity Threshold ("ECT") of no more than five  
21 sustained electric service interruptions in the performance year. The penalties


1 paid, and thus, the number of customers who exceeded the ECT, was lower than  
2 in 2015, 2016, and 2017.

3 For customers experiencing long interruptions, a \$50 bill credit is paid  
4 anytime the Electric Restoration Threshold (“ERT”) of 24 hours is exceeded. In  
5 2018, 198 customers received penalty payment for a total of \$9,900 in bill  
6 credits.

7 **Q. HOW DOES THIS COMPARE TO PREVIOUS QSP DATA?**

8 A. The Company has continuously improved and reduced the number of customers  
9 experiencing multiple interruptions from 2012 to 2018 as shown in the figure  
10 below.

11 **Figure CSN-D-6**



12 The number of customers experiencing long duration outages tends to be lumpy  
13 year over year as there are very few events that can cause customers to

1 experience long duration outages that exceed the 24-hour threshold. The 2018  
2 result—198 customers exceeding the threshold—was an average year when  
3 compared to other years that include a high of 486 customers in 2012 and a low  
4 of 6 customers in 2014.

5 **Q. IS THE COMPANY PROPOSING ANY CHANGES TO THE QSP?**

6 A. Yes, but such changes are limited to the addition of new Adequate Service  
7 metrics that will focus on providing adequate service in conjunction with  
8 improvements to Public Service’s new Electric Distribution Extension Policy  
9 proposed in Consolidated Proceeding 18AL-0852E, which is pending before the  
10 Commission. Tracking mechanisms for these metrics are under development,  
11 and the Company proposes to meet with Staff and OCC quarterly throughout  
12 2019 to share what has been learned, captured and resolved. Company witness  
13 Ms. Applegate discusses these new metrics in her Direct Testimony.

14 **Q. IS THE COMPANY PROPOSING TO EXTEND THE QSP?**

15 A. Yes. Ms. Applegate provides the details and reasons for the Company’s  
16 recommendation to extend the QSP through 2021.

17 **Q. HOW DOES THE COMPANY COMPARE TO ITS PEERS WITH RESPECT TO  
18 SAIDI PERFORMANCE?**

19 A. The Company utilizes the Institute of Electrical and Electronics Engineers  
20 (“IEEE”) Distribution Reliability Working Group large utility group benchmarking  
21 to compare its performance against similar sized electric utilities. The Company  
22 compares itself to other large utilities—that is, utilities with over one million

1 customers. The IEEE survey is voluntary; in 2018, 93 entries were received  
2 (reporting 2017 data), of which 31 were included in the large utilities group.

3 The Company has consistently ranked in the 1st quartile or the top of the  
4 2nd quartile even as overall industry reliability has continued to improve each  
5 year. For the most recent survey year available (2018 survey for 2017 data),  
6 Public Service ranked in the first quartile for 2017 with a SAIDI value of 84.5  
7 minutes. The following table details the Company's rankings for the past eight  
8 years:

9 **Table CSN-D-9**  
**IEEE DRWG Benchmarking (Large Utility Group) – SAIDI**

<b>Year</b>	<b>Quartile</b>	<b>Minutes</b>
2017	1 <sup>st</sup>	84.5
2016	1 <sup>st</sup>	86.5
2015	1 <sup>st</sup>	88.3
2014	1 <sup>st</sup>	84.8
2013	2 <sup>nd</sup>	93.9
2012	1 <sup>st</sup>	93.2
2011	1 <sup>st</sup>	95.1
2010	2 <sup>nd</sup>	94.7

10 **Q. DID THE COMPANY EVER EXPRESS CONCERN REGARDING ITS ABILITY**  
11 **TO CONTINUE TO MAINTAIN ITS RELIABILITY?**

1 A. Yes. In the Direct Testimony of Company witness Mr. John Lee in the AGIS  
2 CPCN Proceeding No. 16A-0588E, Mr. Lee stated that the Company ranked  
3 within the first quartile for SAIDI at that time, but that it was highly unlikely to  
4 maintain that position amongst the Company's peers by 2020 without advancing  
5 the distribution grid. This is because industry expectations are becoming more  
6 stringent as technology for advanced grids develops. It is expected that by 2020  
7 utilities will need a SAIDI of 84 minutes to achieve first quartile SAIDI status, and  
8 that second quartile status will consist of rankings between 84 and 88 minutes.

9 **Q. WITH THE IMPLEMENTATION OF THE AGIS INITIATIVE, DOES THE**  
10 **COMPANY EXPECT TO MAINTAIN ITS FIRST QUARTILE SAIDI RANKINGS?**

11 A. Yes. ADMS, AMI, FLISR and FLP all contribute to improving reliability on the  
12 distribution grid. The Company expects to reduce SAIDI by more than 4.5  
13 minutes by 2020 through the initial implementation of the FLISR initiative and  
14 more than 1 minute through FLP. The Company will work to install these devices  
15 first in the locations that will benefit the most. We continue to strive for  
16 improvement through other areas, including cable replacement, and overhead  
17 protection improvements.

18 While the industry is expected to continue to improve, the Company  
19 expects to continue to be a leader in reliability performance through the  
20 capabilities of the AGIS programs. Even as early as 2020, when these programs  
21 are in the early stages of deployment, they begin having significant impacts on  
22 reliability.

1 **Q. HOW DOES THIS RELIABILITY DISCUSSION RELATE TO THE COMPANY'S**  
2 **OVERALL REQUEST FOR RECOVERY OF AGIS INVESTMENTS IN THIS**  
3 **RATE REVIEW?**

4 A. While the Company has had strong reliability metrics for some time, the  
5 investment in distribution grid advancement is expected to continue to support  
6 and even improve the ability of Public Service to provide reliable electric service.  
7 These outcomes underscore the value and importance of AGIS investments for  
8 the benefit of customers.

1                                    **XI. RECOMMENDATIONS AND CONCLUSION**

2    **Q.    PLEASE SUMMARIZE YOUR RECOMMENDATIONS.**

3    A.    In sum, as part of approving the cost of service developed by Ms. Blair, I  
4        recommend that the Commission approve the 2014-2019 Distribution Business  
5        Area capital additions and 2018 Distribution Business Area O&M expenses,  
6        including the AGIS capital additions and O&M, and adjusted for Mutual Aid to  
7        Puerto Rico, as set forth above. I also recommend the Commission approve the  
8        Company's request related to recovery of Wildfire Mitigation Plan O&M  
9        expenses, which comprise an adjustment to the 2018 O&M expenses for known  
10       and measurable costs.

11   **Q.    DOES THIS CONCLUDE YOUR TESTIMONY?**

12   A.    Yes.

**Statement of Qualifications**

**Chad S. Nickell**

I am the Manager of Distribution System Planning and Strategy—South for Xcel Energy. My role is to provide strategic direction for building a five-year distribution plan for ensuring a reliable and cost effective electric distribution system. My key responsibilities include developing and leading a system advancements and renewal strategy and managing the current year and five-year distribution capital budget for Public Service and Southwestern Public Service Company, one of the other Xcel Energy Operating Companies.

I joined Public Service Company of Colorado in 2008 as a Distribution System Planning Engineer and have over ten years of experience in the utility industry. I graduated from the University of Colorado, Boulder in May 2004 where I earned a Bachelor of Science degree in Electrical Engineering.



BEFORE THE PUBLIC UTILITIES COMMISSION  
OF THE STATE OF COLORADO

\* \* \* \*

RE: IN THE MATTER OF ADVICE )  
NO. 1797-ELECTRIC OF PUBLIC )  
SERVICE COMPANY OF )  
COLORADO TO REVISE ITS ) PROCEEDING NO. 19AL-\_\_\_\_E  
COLORADO P.U.C. NO. 8- )  
ELECTRIC TARIFF TO IMPLEMENT )  
RATE CHANGES EFFECTIVE ON )  
THIRTY-DAYS' NOTICE. )


---

AFFIDAVIT OF CHAD S. NICKELL  
ON BEHALF OF  
PUBLIC SERVICE COMPANY OF COLORADO

---


I, Chad S. Nickell, being duly sworn, state that the Direct Testimony and attachments were prepared by me or under my supervision, control, and direction; that the Direct Testimony and attachments are true and correct to the best of my information, knowledge and belief; and that I would give the same testimony orally and would present the same attachments if asked under oath.

Dated at Denver, Colorado, this 15 day of May, 2019.



Chad S. Nickell  
Manager, System Planning and Strategy - South

Subscribed and sworn to before me this 15<sup>th</sup> day of May, 2019.



Notary Public

My Commission expires April 22, 2022

ROBERT E. BLU, II  
Notary Public  
State of Colorado  
Notary ID # 20104014057  
My Commission Expires 04-22-2022